

CITY OF ALBUQUERQUE



August 23, 2013

Diane Hoelzer, P.E.
Mark Goodwin & Associates, PA
P.O. Box 90606
Albuquerque, NM 87199

**Re: Urban Apartments, 800 Silver Ave. SW
Conceptual Grading and Drainage Plan
Engineer's Stamp Date 7/29/2013 (K13/D013)**

Dear Ms. Hoelzer,

Based upon the information provided in your submittal received 7-30-13, the above referenced plan is approved for Site Plan for Building Permit Administrative Approval with the following condition:

- The curb along the alley should be higher so that it is above the WSE.

If you have any questions, you can contact me at 924-3986.

PO Box 1293

Albuquerque

New Mexico 87103

www.cabq.gov

Sincerely,

Curtis Cherne, P.E.
Principal Engineer, Planning Dept.
Development and Review Services

C: e-mail
file