

CITY OF ALBUQUERQUE



May 27, 2015

Frank Corral, P.E.
CEA Group
4712 Woodrow Bean Suite F
El Paso, TX 79924

RE: **Biopark- Carousel Area**
COA Zoo
Grading and Drainage Plan
Engineers Stamp Date 4/10/15 (K13D034E)

Dear Mr. Corral,

Based upon the information provided in your submittal received 5/20/2015, the above referenced Grading and Drainage Plan cannot be approved for Grading Permit or Building Permit until the following comments are addressed.

- Provide a site plan and FIRMette of this location.
- Provide a table of calculations for land treatments, percentages, existing and proposed flows.
- Provide a legal description of this site.
- Show or mention the location of the bench mark.
- Provide how flows will leave this area.

PO Box 1293

Albuquerque

If you have any questions please contact me at 924-3695 or Rudy Rael at 924-3977.

New Mexico 87103

www.cabq.gov

Sincerely,

Rita Harmon, P.E.
Senior Engineer, Hydrology
Planning Department

RR/RH
C: File