CITY OF ALBUQUERQUE

August 14, 2014



Scott Eddings Huitt-Zollars 6501 America Parkway NE Albuquerque, NM 87110

Re: Silver Moon Apartments

10th St & Park Ave.

Request Permanent C.O. – Not Accepted Engineer's Stamp dated: 5-1-13 (K13D072)

Certification dated: 8-12-14

Dear Mr. Eddings,

Based on the Certification received 8/13/2014, the site is not acceptable for release of Certificate of Occupancy by Hydrology. The following comments must be addressed before CO can be given.

• The plan submitted for CO does not match the approved Grading and Drainage plan.

- We cannot give a partial CO, when the entire site was submitted under one building permit and not in phases.
- The site does not drain in substantial compliance.
- The drainage certification language does not match the hatched areas given on the plan.
- The site is a concern for the safety of its patrons.

New Mexico 87103

PO Box 1293

Albuquerque

If you have any questions, you can contact me at 924-3986 or Rudy Rael at 924-3977.

www.cabq.gov

Sincerely,

Curtis Cherne, P.E.

Principal Engineer, Planning Dept. Development and Review Services

RR/CC

C:

email