DRAINAGE REPORT

for

GRAND PLAZA development



Goldberg · Mann & Associates

Engineers - Plenners

2020 Windowskin N.E.,

Albuquerque, Heur Merico 67110

DRAINAGE REPORT

for

GRAND

PLAZA

development





Goldberg · Mann & Associates

Engineers · Planners

2329 Wisconsin N.E., Suita E

Albuquerque, New Mexico 87110

(505) 282 - 1082

7-37

November 11, 1977

Holmes & Giannini 6400 Uptown Blvd. N.E. Albuquerque, NM 87110

Re: Grand Plaza Development Project

We are herewith submitting three (3) copies of the drainage plan for the Grand Plaza Development Project.

This plan is in accordance with the requirements of the city of Albuquerque and Resolution 1972-2, Albuquerque Metropolitan Arroyo Flood Control Authority.

We have enjoyed working with you on this project and look forward to future opportunities to assist you.

Sincerely yours.

Thomas T. Mann Jr. P.

President

sc

TABLE OF CONTENTS

PURPOSE AND SCOPE

LOCATION AND DESCRIPTION OF PROJECT

DESIGN CRITERA

EXISTING DRAINA(CONDITIONS

PROPOSED DRAINAGE CONDITIONS

CONCLUSIONS


CALCULATIONS


LIST OF FIGURES

FIGURE 1. LOCATION MAP

FIGURE 2. INTENSITY DURATION FREQUENCY CURVES

FIGURE 3. EXISTING TOPOGRAPHY AND GRADING PLAN





NAME:	
ADDRESS:	

PHONE:

6400 Uptown Blvd. Albuquerque NM

BLOCK NO: SUBDIVISION: Belvedere Add STREET ADDRESS: Broadway and Grande N. E. CURRENT ZONING: SU-2

SIGNATURE:

DRAINAGE REPORT FOR GRAND PLAZA DEVELOPMENT PROJECT

PURPOSE AND SCOPE

The purpose of this drainage plan is to establish the criteria for controlling surface runoff from a particular development in a manner that is acceptable to the City of Albuquerque and to the Albuquerque Metropolitan Arroyo Flood Control Authority.

This plan will determine the runoff resulting from a 100-year frequency storm falling on the site of the Grand Plaza Development Project.

The scope of this plan is to insure that the proposed project will be protected from storm runoff and that the construction of this project will not increase the flooding potential of the adjacent properties.

LOCATION AND DESCRIPTION OF PROJECT

The proposed project is located at the intersection of Grand Avenue and Broadway on the northeast corner. The project area is totally within the Martineztown neighborhood development project and contains approximately 2.5 acres.

The proposed project will develop an office complex consisting of seven (7) separate buildings that will have a total leaseable area of 24,256 square feet. There are 109 parking spaces and the development is accessible from both Grand Avenue and Broadway. The site plan delineates two distinct areas, one with three buildings and one with four buildings, each of which faces a circular fountain.

Design Criteria

In analyzing the storm runoff, the Rational Formula, $Q = CIA C_f$ is used.

Where:

- Q = Runoff quantity in cubic feet/second.
- A = Contributing area in acres.
- C_f = Frequency factor for Rational Formula.
- I = Intensity in inches/hour for a duration equal to the time of accumulation (duration) measured in minutes and obtained from Figure 2, Intensity Duration Frequency Curves, Albuquerque Area 1961. (Note: Where a Time of Concentration To is less than ten minutes, the intensity value derived from a To of ten minutes is employed.)
- C = Runoff Coefficient (No Units). This coefficient represents the integrated effects of infiltration, detention storage, evaporation, retention, flow routing, and interception which all affect the time distribution and peak rate of runoff.

EXISTING DRAINAGE CONDITIONS

The existing contours are shown in Figure 3. The land has a uniform slope from southeast to northwest. The property is bordered on the south and west by Grand Avenue N.E. and Broadway Blvd. N.E. respectively, an inverted crown alley on the east and a block wall to the north. Thus there are no off-site flows entering the site. At the present time all storm waters from the site flow into Broadway Blvd.

There is an existing double 'c' drop inlet at the east northeast curb return of the intersection. There are 30" and 48" storm drains in Grand Avenue and Broadway Blvd. respectively, and the existing runoff from the property is approximately 4.5 cfs.

PROPOSED DRAINAGE CONDITIONS

The proposed grading plan is shown in Figure 3. The proposed drainage plan utilizes a series of ponds and some discharge to Broadway Blvd. to achieve the goal of reduced storm runoff from the property.

The parking area along the north side of the property will be allowed to drain into Broadway Blvd. and approximately 2.6 cfs will enter the street. The undeveloped flow is approximately 4.5 cfs.

All other flows will be directed into ponding areas as shown in Figure 3. Approximately 10,870 cubic feet of storage will be provided. This exceeds the required storage of 8280 cubic feet.

CONCLUSIONS

The following conclusions and recommendations are made for the development of Grand Plaza.

- Allow flow from parking lot along the north side of the property to flow into Broadway Blvd.
- 2. Flow from site is approximately 4.5 cfs in the undeveloped state and 2.6 in the developed state.
- 3. Direct all other flows into ponds. The required pond storage is 8280 cubic feet. The storage provided is approximately 10,870 cubic feet.

CALCULATIONS

UNDEVELOPED FLOYS

area =
$$497 \frac{185+233}{2}$$
 = 103,873 sq. ft. = 2.4 acres

T_c = 10 minutes

$$I = \frac{189}{10+25} = 5.4 \text{ inches per hour}$$

$$Q = 0.35 (5.4) 2.4 = 4.5 cfs$$

DEVELOPED FLOWS

Area draining to Broadway

2.4 acres

Required pond volume = 82764 x 0.1 = 8280 cubic feet
Pond volumes

1.
$$\frac{2990+625}{2} \times 2 = 3616$$

 $625 \times .5 = \frac{312}{3928}$

2.
$$1300 \times 1 = 1300$$

 $300 \times .5 = 150$
 1450
1450

3.
$$\frac{(26\times52)+(18\times45)}{2} \times 1 = 1861$$

$$18\times45\times.5$$

$$\frac{405}{2266}$$
2266

4.
$$\frac{(150 \times 12) + (142 \times 4)}{2} \times 1 = 1184$$

$$142 \times 4 \times .25 = \frac{142}{1326}$$
1326

5.
$$\frac{(47\times40)+(32\times30)}{2}$$
 x 1 = 1420
32x30x.5 = $\frac{480}{1900}$
Total Storage = 10870 cf

Flow to Broadway Blvd.
Q = 0.95 (5.4) .5 m 2.5 cfs

