HYDROLOGY K14/D25 NO PLANS

K14|D25

NO PLANS

CITY OF ALBUQUERQUE

ALBUQUERQUE, NEW MEXICO

INTER-OFFICE CORRESPONDENCE

July 9, 1985

REF. NO._____

TO: Sandy Zuschlag, Assistant Park Designer, Parks & Recreation

FROM: Carlos A. Montoya, P.E., City/County Floodplain Admin.; Design Hydrology CM

SUBJECT: REQUEST FOR VARIANCE TO THE REQUIRED DRAINAGE PLAN FOR GUADALUPE PARK

The City Ordinance indicates that repairing an existing paved area in which no grading is planned does not require a drainage plan. Also, a drainage plan is not needed if the project involves less than 500 cubic yards of soil material.

If both these conditions are met, a drainage plan will not be required. We will start a file on this project.

If you have any questions or comments, please call me at 76[illegible]-7644.

CAM/bsj

CITY OF ALBUQUERQUE

ALBUQUERQUE, NEW MEXICO

RECEIVED
JUN 20 1985
CITY ENGINEER

INTER-OFFICE CORRESPONDENCE June 17, 1985

RECEIVED
JUN 21 1985
DHO179
HYDROLOGY SECTION

REF. NO.

TO: Fred Aguirre, Design Hydrologist, MD

FROM: Sandy Zuschlag, Assistant Park Designer, Parks & Recreation SZ

SUBJECT: Reply to Comments of Guadalupe Park

As a result of Guadalupe Park being a renovation with little change in topography, I would like to ask you to consider a variance to the required drainage plan. The draingage from the site will remain the same or even decrease due to the removal of asphalt and the addition of turf and planter beds. The remainder of the project is resurfacing the existing basketball court (which is nearly 50% of the site).

If you have any questions about the proposed variance of Guadelupe or would like to arrange a meeting to further discuss this variance, please call me at 823-4012.

SZ:lc

cc: Andre Houle, Quality Assurance

CITY OF ALBUQUERQUE

ALBUQUERQUE, NEW MEXICO

RECEIVED
JUL 08 1985
HYDROLOGY SECTION

INTER-OFFICE CORRESPONDENCE

May 29, 1985

TO: Sandra Zuschlag, Assistant Park Designer; Parks & Recreation

FROM: Fred J. Aguirre, P.E., Design Hydrologist; Engineering Division

SUBJECT: PRELIMINARY REVIEW & COMMENTS FOR RENOVATION OF GUADALUPE PARK

An approved drainage plan is required per the D.P.M. if the proposed development involves grading of 1 acre or more, any cut or fill of 500 cubic yards or more, or paving of 1000 square feet or more.

Please forward the required drainage submittal to this office for review and approval if any of the above developments are proposed.

FJA/bsj

write letter to Carmen

RECEIVED
JUN 5 1985
PARKS & RECREATION DEPARTMENT

CITY OF ALBUQUERQUE

ALBUQUERQUE, NEW MEXICO

RECEIVED
JUL 08 1985
HYDROLOGY SECTION

INTER-OFFICE CORRESPONDENCE May 16, 1985

TO: SEE DISTRIBUTION

FROM: Sandra Zuschlag, Assistant Park Designer, Parks & Recreation

SUBJECT: Preliminary Review & Comments for Guadalupe Park

The construction drawings for Guadalupe Park are ready for preliminary review and comments. Please have your comments returned by May 31, 1985.

Please call if you have any questions.

SZ:lc

DISTRIBUTION:
Orlando Sedillo, Director, Parks & Recreation
Marty Valdez, Assistant Director, Parks & Recreation
Janet Saiers, Planner, Parks & Recreation
Pete Turpin, Superintendent, Park Management
Fred Aguirre, MDD, Engineering/Hydrology
Dwayne Sheppard, City Engineer, MDD
Andre Houle, Civil Engineer, Quality Assurance
Basker Vedamanikam, Water Resources
Dave Harmon, Traffic Engineering
Larry Caudill, Environmental Health
Jim Graf, Van Gilbert Architectural Office