

October 24, 1996

Martin J. Chávez, Mayor

Mark Goodwin
Mark Goodwin & Assoc.
P.O. Box 90606
Albuquerque, NM 87199


**RE: GOOD SHEPHERD ADDITION (K14-D35). ENGINEER'S CERTIFICATION
FOR CERTIFICATE OF OCCUPANCY APPROVAL. ENGINEER'S
CERTIFICATION DATED OCTOBER 21, 1996.**

Dear Mr. Goodwin:

Based on the information provided on your October 21, 1996
submittal, the above referenced project is approved for
Certificate of Occupancy.

If I can be of further assistance, please feel free to contact me
at 768-3622.

Sincerely,



Lisa Ann Manwill
Engineering Assoc./Hyd.

c: Andrew Garcia
File

Good for You, Albuquerque!



DRAINAGE INFORMATION SHEET

PROJECT TITLE: Good Shepherd Addition ZONE ATLAS/DRNG, FILE#: K-14 / 1035
DRB #: _____ EPC #: _____ WORK ORDER #: _____
LEGAL DESCRIPTION: Lot 1A, Block F, Pacific Addition
CITY ADDRESS: Iron and 2nd SW

ENGINEERING FIRM: Mark Goodwin & Associates CONTACT: Mark Goodwin PE
ADDRESS: PO Box 90606 PHONE: 345-2010
OWNER: Good Shepherd CONTACT: Jim Lewis
ADDRESS: 1620 Central SE PHONE: 247-1529
ARCHITECT: SLNB Architects CONTACT: Jim Lewis
ADDRESS: 1620 Central SE PHONE: 247-1529
SURVEYOR: ALS, Inc. CONTACT: Tim Aldrich
ADDRESS: PO Box 30701 PHONE: 884-1990
CONTRACTOR: Sierra Development CONTACT: GREG LUTZ
ADDRESS: _____ PHONE: 251-6638

TYPE OF SUBMITTAL:

____ DRAINAGE REPORT
____ DRAINAGE PLAN
____ CONCEPTUAL GRADING & DRAINAGE PLAN
____ GRADING PLAN
____ EROSION CONTROL PLAN
☒ ENGINEER'S CERTIFICATION
____ OTHER

CHECK TYPE OF APPROVAL SOUGHT:


____ SKETCH PLAT APPROVAL
____ PRELIMINARY PLAT APPROVAL
____ S. DEV. PLAN FOR SUB'D APPROVAL
____ S. DEV. PLAN FOR BLDG PERMIT APPROVAL
____ SECTOR PLAN APPROVAL
____ FINAL PLAT APPROVAL
____ FOUNDATION PERMIT APPROVAL
____ BUILDING PERMIT APPROVAL
☒ CERTIFICATION OF OCCUPANCY APPROVAL
____ GRADING PERMIT APPROVAL
____ PAVING PERMIT APPROVAL
____ S.A.D. DRAINAGE REPORT
____ DRAINAGE REQUIREMENTS
____ OTHER _____ (Specify)

PRE-DESIGN MEETING:

____ YES
☒ NO
____ COPY PROVIDED

DATE SUBMITTED: 10/21/96

BY: Mark Goodwin
Mark Goodwin PE



DRAINAGE INFORMATION SHEET

PROJECT TITLE: Good Shepherd Addition ZONE ATLAS/DRNG, FILE#: K-14 / 35
DRB #: _____ EPC #: _____ WORK ORDER #: _____
LEGAL DESCRIPTION: Lot 1A, Block F, Pacific Addition
CITY ADDRESS: Iron and 2nd SW

ENGINEERING FIRM: <u>Mark Goodwin & Associates</u>	CONTACT: <u>Mark Goodwin PE</u>
ADDRESS: <u>PO Box 90606</u>	PHONE: <u>345-2010</u>
OWNER: <u>Good Shepherd</u>	CONTACT: <u>Jim Lewis</u>
ADDRESS: <u>1620 Central SE</u>	PHONE: <u>247-1529</u>
ARCHITECT: <u>SLNB Architects</u>	CONTACT: <u>Jim Lewis</u>
ADDRESS: <u>1620 Central SE</u>	PHONE: <u>247-1529</u>
SURVEYOR: <u>ALS, Inc.</u>	CONTACT: <u>Tim Aldrich</u>
ADDRESS: <u>PO Box 30701</u>	PHONE: <u>884-1990</u>
CONTRACTOR: <u>N/A</u>	CONTACT: _____
ADDRESS: _____	PHONE: _____

TYPE OF SUBMITTAL:

☐ DRAINAGE REPORT
☒ DRAINAGE PLAN
☐ CONCEPTUAL GRADING & DRAINAGE PLAN
☒ GRADING PLAN
☐ EROSION CONTROL PLAN
☐ ENGINEER'S CERTIFICATION
☐ OTHER

PRE-DESIGN MEETING:

☐ YES
☒ NO
☐ COPY PROVIDED

CHECK TYPE OF APPROVAL SOUGHT:

☐ SKETCH PLAT APPROVAL
☐ PRELIMINARY PLAT APPROVAL
☐ S. DEV. PLAN FOR SUB'D APPROVAL
☐ S. DEV. PLAN FOR BLDG PERMIT APPROVAL
☐ SECTOR PLAN APPROVAL
☐ FINAL PLAT APPROVAL
☐ FOUNDATION PERMIT APPROVAL
☒ BUILDING PERMIT APPROVAL
☐ CERTIFICATION OF OCCUPANCY APPROVAL
☐ GRADING PERMIT APPROVAL
☐ PAVING PERMIT APPROVAL
☐ S.A.D. DRAINAGE REPORT
☐ DRAINAGE REQUIREMENTS
☐ OTHER _____ (Specify)

DATE SUBMITTED: 12/8/95

BY: Mark Goodwin
Mark Goodwin PE



D. Mark Goodwin & Associates, P.A.
Consulting Engineers and Surveyors

PROJECT Good Shepard
SUBJECT Drainage
BY MG DATE 12/7/95
CHECKED _____ DATE _____
SHEET 1 OF 1

This project entails construction of a small addition to an existing facility and paving an existing gravel parking lot.

Area of Improvements = 0.18 Ac.

Prec. Zone 1

Existing Land Treatments:

A = 0%

B = 30%

C = 70%

D = 0

Proposed Land Treatments:

A = 0

B = 19%

C = 5%

D = 76%


Existing Q = 0.51 cfs

Proposed Q = 0.75 cfs Negligible

DEC 11 1995



- Z NOTES



OF 00