HYDROLOGY K14/D35 2 PLANS

K14/D35

2 PLANS

FILE COPY

City of Albuquerque

P.O. BOX 1293 ALBUQUERQUE, NEW MEXICO 87103

HYDROLOGY SECTION
123 Central NW, Albuquerque, NM 87102
(505) 766-7644

July 31, 1986

Joseph C. Brawley
Schlegel Lewis & Associates, Inc.
1620 Central Avenue, SE
Albuquerque, New Mexico 87106

RE: DRAINAGE PLAN FOR LITTLE BROTHERS OF THE GOOD SHEPARD
(K-14/D35) RECEIVED JULY 28, 1986

Dear Mr. Brawley:

We have reviewed the site plan and have field verified the site. Due to the following reasons, we are not requesting a drainage plan:

1. Minimum increase in impervious area.
2. Major storm drain systems in Iron Street.
3. Site is not in a flood zone.
4. Minimum impact on downstream facilities.
5. Site is in a fully developed watershed.

We do request that the roof drains be placed along the north side of addition and routed to the existing drivepad.

If you have any questions, call me at 766-7644.

Cordially,

Carlos A. Montoya

Carlos A. Montoya, P.E.
City/County Floodplain Administrator

CAM/bsj

DRAINAGE INFORMATION SHEET

PROJECT TITLE: Little Brother of Good Shepherd ZONE ATLAS/DRNG. FILE #: K14/D35

LEGAL DESCRIPTION: Atlantic & Pacific Addn. Block F Lots 1-9 Portion of Lots 10-12

CITY ADDRESS:

ENGINEERING FIRM: CONTACT:

ADDRESS: PHONE:

OWNER: CONTACT:

ADDRESS: PHONE:

→ ARCHITECT: JOSEPH C. BRAWLEY CONTACT:

ADDRESS: 1620 CENTRAL AVE SE ALBQ. NM 87106 247-1529 PHONE:

SURVEYOR: CONTACT:

ADDRESS: PHONE:

CONTRACTOR: CONTACT:

ADDRESS: PHONE:

RECEIVED JUL 28 1986 HYDROLOGY SECTION

PRE-DESIGN MEETING:

X YES

___ NO

___ COPY OF CONFERENCE RECAP SHEET PROVIDED

DRB NO. ___

EPC NO. ___

PROJ. NO. ___

TYPE OF SUBMITTAL:

___ DRAINAGE REPORT

___ DRAINAGE PLAN

___ CONCEPTUAL GRADING & DRAINAGE PLAN

___ GRADING PLAN

___ EROSION CONTROL PLAN

___ ENGINEER'S CERTIFICATION

X field varification

CHECK TYPE OF APPROVAL SOUGHT:

___ SKETCH PLAT APPROVAL

___ PRELIMINARY PLAT APPROVAL

___ SITE DEVELOPMENT PLAN APPROVAL

___ FINAL PLAT APPROVAL

X BUILDING PERMIT APPROVAL

___ FOUNDATION PERMIT APPROVAL

___ CERTIFICATE OF OCCUPANCY APPROVAL

___ ROUGH GRADING PERMIT APPROVAL

___ GRADING/PAVING PERMIT APPROVAL

___ OTHER ___ (SPECIFY)

X Not in a floodzone

X storm drain in Iron

DATE SUBMITTED:

BY: