

CITY OF ALBUQUERQUE
MUNICIPAL DEVELOPMENT DEPARTMENT
ENGINEERING DIVISION/DESIGN HYDROLOGY SECTION

CONFERENCE RECAP

DRAINAGE FILE/ZONE ATLAS PAGE NO.: K-14 DATE: 10-23-86
PLANNING DIVISION NOS: EPC: _____ DRB: 85-420
SUBJECT: Apartment
STREET ADDRESS (IF KNOWN): Corner of HIGH & LEAD
SUBDIVISION NAME: LOTS 1A thru 3B BLOCK 29 HIGHLAND
ADDITION

APPROVAL REQUESTED:

☐ PRELIMINARY PLAT	☐ FINAL PLAT
☐ SITE DEVELOPMENT PLAN	☒ BUILDING PERMIT
☐ OTHER	☐ ROUGH GRADING

	WHO	REPRESENTING
ATTENDANCE:	<u>John Mortensen</u>	<u>Tam Mann & Assoc.</u>
	<u>Roger Green</u>	<u>CITY of Hydrology</u>

FINDINGS:

- ① Approved Grading & Drainage Plan required for Building Permit signed by Hydrology
- ② Require either a replat to eliminate lots lined or create a reciprocal drainage and access easement between lots.
- ③ If alley is used for drainage or access purposes then approved ~~to~~ alley grades are required prior to Building Permit release.
- ④ Free discharge to Lead or High Street is approved.

The undersigned agrees that the above findings are summarized accurately and are only subject to change if further investigation reveals that they are not reasonable or that they are based on inaccurate information.

SIGNED: Roger A. Green Jr.
TITLE: Civil Engineer
DATE: 10-23-86

SIGNED: [Signature]
TITLE: _____
DATE: 10-23-86