CITY OF ALBUQUERO

Planning Department Alan Varela, Director



Mayor Timothy M. Keller

June 17, 2022

Kristina Werenko MRWM Landscape Architects 1102 Mountain Rd NW Albuquerque, NM 87102

Re: City of Albuquerque Bareras Park Renovation **801 Bareras Park Renovation**

Traffic Circulation Layout

Engineer's/Architect's Stamp 06-07-2022 (K14-D047)

Dear Ms. Werenko,

The TCL submittal received 06-16-2022 is approved for Building Permit. A copy of the stamped and signed plan will be needed for each of the building permit plans. Please keep the original to be used for certification of the site for final C.O. for Transportation.

PO Box 1293

Albuquerque

When the site construction is completed and an inspection for Certificate of Occupancy (C.O.) is requested, use the original City stamped approved TCL for certification. Redline any minor changes and adjustments that were made in the field. A NM registered architect or engineer must stamp, sign, and date the certification TCL along with indicating that the development was built in "substantial compliance" with the TCL. Submit this certification, the TCL, and a completed Drainage and Transportation Information Sheet to front counter personnel for log in and evaluation by Transportation.

NM 87103

Once verification of certification is completed and approved, notification will be made to Building Safety to issue Final C.O. To confirm that a final C.O. has been issued, call Building Safety at 924-3690.

www.cabq.gov

Sincerely,


Jeanne Wolfenbarger, P.E.


sanne Wolfenbarger


Traffic Engineer, Planning Dept.


Development Review Services

/xxx via: email C: CO Clerk, File









ORMA T

BENCH MARKS

DATE

MEDIAN C&G


COA STD DWG #2443



COA STD DWG #2415A

TRAFFIC CIRCULATION LAYOUT APPROVED 06/16/2022

Jeanne Wolfenbarger



MODIFIED ADA RAMP

WILSON		I
&COMPANY 4401 MASTHEAD ST. NE. S	UITE 150	
ALBUQUERQUE, NM 8 PHONE: 505-348-400	00	L
FAX: 505-348-4072 www.wilsonco.com		- -

NDSCAPE ARCHITECTS


mla.com 505 268 2266 TY OF ALBUQUERQUE


STRATEGIC PLANNING AND DESIGN PARKS AND RECREATION DEPARTMENT

BARELAS PARK RENOVATION

TRAFFIC CIRCULATION LAYOUT DETAILS

Design Review Committee | City Engineer Approval City Project No. Zone Map No. 615792 K-13 & K-14 C-107





4" PCC SIDEWALK DETAIL

CONSTRUCTION NOTES

REQUIRED.

4" PCCf'c = 3000 PSI @ 28DAYS PER SECTION 101

1.5% TYP

1 WHEN ABUTTING TO VERTICAL WALLS, BENCHES OR

2 EXPANSION JOINTS SHALL BE SPACED 40' MAX

3 INSTALL CONTRACTION JOINTS AT 6'-0" OC 4 LIGHT BROOM FINISHED CONCRETE SURFACE

BUILDINGS, INSTALL 1/2" BITUMINOUS EXPANSION JOINT. RECESS 1/4" VERTICALLY. INSTALL SIKA-FLEX POLYMER


SEALANT OR APPROVED EQUAL PER SECTION 107 (TYP)


2% MAX


PER SECTION 302.

12" SUBGRADE PREP COMPACTED TO 95% MIN DENSITY PER

SECTION 301







BIKE RACK DETAILS