

CITY OF ALBUQUERQUE
PUBLIC WORKS DEPARTMENT
UTILITY DEVELOPMENT DIVISION/HYDROLOGY SECTION

PRE-DESIGN CONFERENCE

DRAINAGE FILE/ZONE ATLAS PAGE NO.: K-14

DATE: 7/27/90

EPC NO.: _____ DRB NO.: _____ ZONE: _____

SUBJECT: HIGHLAND MEDICAL STORAGE AREA

STREET ADDRESS: CENTRAL / BROADWAY


LEGAL DESCRIPTION: Lot 3 & 4, Block 9, HUNING, HIGHLAND ADDITION

APPROVAL REQUESTED: _____ PRELIMINARY PLAT _____ FINAL PLAT

_____ SITE DEVELOPMENT PLAN _____ BUILDING PERMIT

X _____ GRADING/PAVING PERMIT _____ OTHER _____

ATTENDANCE: MARK GOODWIN MARK GOODWIN & ASSOC.
GILBERT ALPHE CITY OF ALBUQ



FINDINGS:

- 1.) PAVING OF Lot 3 & 4 to FREE DISCHARGE
THROUGH ALLEY & INTO GOLD AVENUE
- 2.) Will IMPROVE ALLEY SECTION To CONVEY
Flows To GOLD AVENUE, Flows Not Allowed
To SHEETFLOW INTO CHURCH PROPERTY
- 3.) No Work Order Drawings Required For ALLEY
If Engineer Will Obtain SIGNATURE & FROM
TRANSPORTATION & DRG CHAIRMAN
- 4.) No EASEMENT Required IF THE LOTS 3 & 4
BELONG TO SAME OWNER AND OWNER ATTEST
ON PLAN THIS IS THE CASE TO ALLOW
Cross Lot DRAINAGE.

The undersigned agrees that the above findings are summarized accurately and are only subject to change if further investigation reveals that they are not reasonable or that they are based on inaccurate information.

SIGNED: [Signature]

TITLE: Civil Eng

DATE: 7/27/90

SIGNED: Mark Goodwin

TITLE: _____

DATE: 7/27/90

NOTE PLEASE PROVIDE A COPY OF THIS PRE-DESIGN FORM WITH THE DRAINAGE SUBMITTAL.