

# CITY OF ALBUQUERQUE



October 14, 2016

David Tull, P.E.  
Superior Stormwater Services, LLC  
8505 Paseo Alameda NE  
Albuquerque, NM 87113

**Re: Innovate ABQ  
Erosion and Sediment Control Plan  
Engineer's Stamp Date 10-7-16 (K14E108)**

Dear Mr. Tull,

Based upon the information provided in your submittal received 10-14-16 the above referenced plan is approved to be included in the SWPPP and to apply for an ESC Permit for Building Permit with the following conditions:

1. Provide inlet protection for area drains specified as Keyed Notes 3 and 4 on the grading and drainage plan.
2. If sediment/debris are present west of the "Limits of Disturbance" shown on the ESC plan: inlet protection is provided for the area inlet in the middle of the parking lot to the west and the mulch sock or similar is provided upstream of the channel in the southwest corner.

Include a copy of the approved plan in the Building Permit set.

If you have any questions, you can contact me at 924-3420.

Sincerely,

Curtis Cherne, P.E.  
Principal Engineer, Stormwater Quality  
Planning Dept.

C: email