



Phillip B Gallegos Jr <acequia.architects@gmail.com>

Fire Plan1

2 messages

Phillip B Gallegos Jr <acequia.architects@gmail.com>

Tue, Dec 7, 2021 at 9:06 AM

To: "Pavatt, Laura J." <lpavatt@cabq.gov>

Cc: Ron Romero <ronromeroinc@gmail.com>, Kristen Madden <Kristenmadden.aphp@gmail.com>, Andrea Plaza <andrea@encuentronm.org>

Ms. Pavatt

Thank you for the information on a Fire1 plan.

The checklist seems to indicate requirements for a new building.

Per our discussion, our project is renovation of an existing building located at 907 4th Street SW.

The project number is BP-2021-37153 and we have prepared a fire2 plan of the building and prepared to upload it.

The transportation engineer, Mr Nilo Salgado, indicated the wanted a fire1 plan approval

To refresh the information I provided, the renovation will not add any square footage.

The building currently has a fire sprinkler system and detection along with alarms and annunciators.

The fire2 plan we are prepared to upload and we can send it to you if you wish to see it prior to the upload.

The copy of what we will attach to the final submission for fire2 is at the end of this email

Is a fire1 plan not required as we discussed?

Thanks for your help.

Phillip Gallegos, Architect

303.883.9286

**FIRE 2 PLAN.pdf**

698K

Pavatt, Laura J. <lpavatt@cabq.gov>

Wed, Dec 8, 2021 at 11:00 AM

To: Phillip B Gallegos Jr <acequia.architects@gmail.com>

Good morning,

I don't see any deficiencies in the fire 2. It just needs to be submitted with the plan set for review. A fire 1 page is not required when the project is an existing building and no new square footage is being added and the sprinkler system is existing.

Take care,

Inspector Laura Pavatt

Fire Marshal's Office Plans Check Division

Albuquerque Fire Rescue600 2nd ST NW

Albuquerque NM 87102

Tel 505-924-3611



From: Phillip B Gallegos Jr <acequia.architects@gmail.com>

Sent: Tuesday, December 7, 2021 9:07 AM

To: Pavatt, Laura J. <lpavatt@cabq.gov>

Cc: Ron Romero <ronromeroinc@gmail.com>; Kristen Madden <Kristenmadden.aphp@gmail.com>; Andrea Plaza <andrea@encuentronm.org>

Subject: Fire Plan1

External

[Quoted text hidden]