CITY OF ALBUQUERQUE

Planning Department Brennon Williams, Director



Mayor Timothy M. Keller

March 6, 2022

Alejandro Sazo RBA Architecture 1104 Park Ave Albuquerque, NM 87102

Re: Edith 4-Plex
725 Edith Blvd SE
Traffic Circulation Layout
Architect's Stamp 11-30-2021 (K14-D228)

Dear Mr. Sazo,

Based upon the information provided in your submittal received 03-04-2022, the above referenced plan cannot be approved for Building Permit until the following comments are addressed:

PO Box 1293

- 1. Provide proposed concrete design (Keyed 19). Thickness should be great 6 inche or greater. Include dowels if required by design.
- 2. **Detail A10/AS-2.):** Provide slopes for landing (50:1 max) and specify ramp run as 12:1 *MAX*.

Albuquerque

3. Motorcycle parking space: Label pavement MC.

NM 87103

- 4. Curbing should be installed to delineate landscape, and pedestrian ways and identify points of access. Please call out detail and location of barrier curb.
- 5. Provide a copy of refuse approval.

www.cabq.gov

- 6. Fire Department: An approval Fire 1 plan needs to be provided (If applicable by FD).
- 7. Add a note stating "All broken or cracked sidewalk must be replaced with sidewalk and curb & gutter." A build note must be provided referring to the appropriate City Standard drawing (2430 & 2415A).
- 8. Please provide a letter of response for all comments given.

Once corrections are complete resubmit

- 1. The Traffic Circulation Layout
- 2. A Drainage Transportation Information Sheet (DTIS)
- 3. Send an electronic copy of your submittal to PLNDRS@cabq.gov.
- 4. The \$75 re-submittal fee.

for log in and evaluation by Transportation.

CITY OF ALBUQUERQUE

Planning Department Brennon Williams, Director



Mayor Timothy M. Keller

PO Box 1293

Albuquerque

NM 87103

www.cabq.gov

	If you have any questions, please contact me at (505) 924-3630.	
	Since	
/		
		algado Fernandez, P.E.
		r Traffic Engineer, Planning Dept.
	Development Review Services	
	C:	CO Clerk, File
		,