


# CITY OF ALBUQUERQUE



October 12, 2005

David A. Aube, P.E.  
The Design Group  
202 Central Ave. Suite 200  
Albuquerque, NM 87106

**Re: ARMC Site Renovations, Walter St. Grading and Drainage Plan**  
**Engineer's Stamp dated 9-28-05 (K15-D6G)**

Dear Mr. Aube,

Based upon the information provided in your submittal received 10-03-05, the above referenced plan cannot be approved for Grading Permit until the following comments are addressed:

P.O. Box 1293

1. Show all proposed and existing drainage infrastructure. How will the low spots drain?
2. A narrative would be helpful in lieu of drainage calculations.
3. A legend would also be helpful.

Albuquerque

If you have any questions, you can contact me at 924-3986.

New Mexico 87103

Sincerely,

Bradley L. Bingham, PE  
Principal Engineer, Planning Dept.  
Development and Building Services

[www.cabq.gov](http://www.cabq.gov)

C: file