


CITY OF ALBUQUERQUE



November 4, 2005

David Aube, P.E.
The Design Group
202 Central Ave. SE Suite 200
Albuquerque, NM 87102

**Re: ARMC Site Renovations, Intersection of Walter Drive / Martin Luther
King Jr. Avenue, Grading and Drainage Plan
Engineer's Stamp dated 10-28-05 (K15-D6G)**

Dear Mr. Aube,

Based upon the information provided in your submittal received 10-31-05, the above referenced plan is approved for Paving Permit and Grading Permit. However, please note that the flow line elevation shown approximately 40 feet east of Walter Drive would create a low point. Please correct this elevation. Upon completion of the project, please provide an Engineer Certification for our files.

P.O. Box 1293

Albuquerque

New Mexico 87103

www.cabq.gov

If you have any questions, you can contact me at 924-3981.

Sincerely,

Kristal D. Metro, P.E.
Senior Engineer, Planning Dept.
Development and Building Services

C: File