City of Albuquerque Stormwater Construction Site Inspection Report

General Information

Project Name:	Broadstone Highlands		
Location:	Cedar & Copper		
Site Contact Name & Agency	Lee Riley	ESC File No.	K15E034A
	Alliance	NPDES Id. No.	NMR 1000VI
Inspection Date:	5-3-19	Start/End Time:	10:45
CoA Stormwater Inspector:	Curtis Cherne		
Construction Phase:	export, clearing		

Type of Inspection: [X] Regular [ ] Storm Event [ ] Post Storm Event >0.25" [ ] 311/Complaint [ ] Follow Up

Weather at time of inspection? Clear	Temperature: ~ 60
Estimated date of last storm 0.25" or greater 4-22-19	

Item Number	Deficiency/ Corrective Action
1.	gap in sediment BMP south side
2.	hauling dirt across street - no track-out pad
3.	sediment in street
4.	site not posted
5.	no inlet protection Copper Ave.
2.1	Discharge off site? (Y/N)
4	Self Inspection Reports — request — Latest report Date:

Notes:

inlet SW corner
existing domestic trash north edge of site - outside fence

City of Albuquerque Stormwater Inspector Signature and date: Curtis C Cherne 5-3-19

Contact information: Curtis Cherne, 505-924-3420
ccherne@cabq.gov