




KEN SCHULTZ  
MAYOR

# City of Albuquerque

P.O. BOX 1293 ALBUQUERQUE, NEW MEXICO 87103

May 18, 1989

Pat Conley  
Bovay Engineering  
3125 Carlisle Boulevard, NE  
Albuquerque, New Mexico 87109



RE: DRAINAGE PLAN FOR HORIZON NURSING CENTER  
(K-15/D50) RECEIVED MAY 10, 1989

Dear Mr. Conley:

I have reviewed the referenced plan and forward the following comments:

- ✓ 1. Please show roof drain.
- ✓ 2. Need a one foot water block for the entrance from Grand Avenue.
- ✓ 3. Please show where there is a 6" curb.
- ✓ 4. Will there be new curb and gutter at the sidewalk culvert area? *yes*
- ✓ 5. Please correct your time of concentrations.

Should you have any questions, please call me at 768-2650.

Cordially,

Carlos A. Montoya, P.E.  
City/County Floodplain Administrator

CAM/bsj  
(WP+1104)

✓ TRA 5/18/89