

From: Patz, Logan W.
To: ["Kent Beierle"](#)
Cc: [Ortiz, Monica](#); [Al-Najjar, Marwa G.](#)
Subject: The Cage, 4100 Central SE, K17D114
Date: Friday, August 11, 2017 2:10:00 PM
Importance: High

Hello Kent,

This plan was going through for building permit and a concern was brought to our attention. The walls on the parking structure appear to be solid and will obstruct the drivers view from potential pedestrians.

We would like to add two conditions for approval of final inspection. The conditions would be to add convex mirrors at the point of egress and signage stating "Slow watch for pedestrians".

-

Let us know if there is an issue or if you have any questions.

Thank you.

-

-

Logan Patz

Planning Department
Transportation Development
600 2nd St. NW, Suite 201
Albuquerque, NM 87102
505-924-3630