



City of Albuquerque Stormwater Construction Site Inspection Report

General Information

ESC File No.	K17E118	Project Name:	FNCH Behavioral Health Outpatient Clinic		
NPDES Id. No.	NMRI005Y3	Location:	5110 Copper Ave NE		
2/6/2025	Owner	Contractor			
Operator	First Nations Community Healthsource	Enterprise Builders Corp			
Contact name & title	Linda Son-Stone	Darren Lewis			
e-mail	linda.son-stone@fnch.org	dlewis@ebnm.com			
Contact Phone #	505-262-2481	505-263-3951			
COA Inspector	Chancellor English	Start/End Time:	11:30am		
Construction Phase:	verticals, landscaping				
Type of Inspection:	<input checked="" type="checkbox"/> Regular	<input type="checkbox"/> Storm Event	<input type="checkbox"/> Post Storm Event >0.25"	<input type="checkbox"/> 311/Complaint	<input type="checkbox"/> Follow Up
Weather at time of inspection?	Clear		Temperature: ~	65	
Estimated date of last storm 0.25" or greater	11/7/2024				

Item Number	Deficiency/ Corrective Action			
1	SWPPP - The self-inspection reports were not available at the time of the inspection in violation of CGP Part 4.7.3. Required mitigation: You must keep a copy of all inspection reports at the site or at an easily accessible location so that they can be made immediately available during the time of an on-site inspection per CGP Part 4.7.3.			
2.1	Discharge off site? (Y/N)	no		
4	Self Inspection Reports	No	Latest report Date:	N/A

Notes:	

City of Albuquerque Stormwater Inspector Signature and date: 2/6/2025
Contact information: Chancellor English (505) 924-3325
cenglish@cabq.gov

Chancellor English