HYDROLOGY K18/D15 2 PLAN

K18/D15

2 PLANS

DRAINAGE INFORMATION SHEET

PROJECT TITLE: Storage Addition ZONE ATLAS/DRNG. FILE #: K18/D15

LEGAL DESCRIPTION: Fairgrounds Add; Lot 19 & 20 Blk 12

CITY ADDRESS: 312 Dakota SE

ENGINEERING FIRM: _____ CONTACT: _____

ADDRESS: _____ PHONE: _____

OWNER: _____ CONTACT: _____

ADDRESS: _____ PHONE: _____

ARCHITECT: _____ CONTACT: _____

ADDRESS: _____ PHONE: _____

SURVEYOR: _____ CONTACT: _____

ADDRESS: _____ PHONE: _____

CONTRACTOR: Agri Bldg Co CONTACT: Lori Harris

ADDRESS: 4330 Broadway SE PHONE: 877-4155

PRE-DESIGN MEETING:

___ YES

___ NO

___ COPY OF CONFERENCE RECORD SHEET PROVIDED

RECEIVED NOV 12 1987 HYDROLOGY SECTION

DRB NO. _____

EPC NO. _____

PROJ. NO. _____

TYPE OF SUBMITTAL:

___ DRAINAGE REPORT

___ DRAINAGE PLAN

___ CONCEPTUAL GRADING & DRAINAGE PLAN

___ GRADING PLAN

___ EROSION CONTROL PLAN

___ ENGINEER'S CERTIFICATION

CHECK TYPE OF APPROVAL SOUGHT:

___ SKETCH PLAT APPROVAL

___ PRELIMINARY PLAT APPROVAL

___ SITE DEVELOPMENT PLAN APPROVAL

___ FINAL PLAT APPROVAL

___ BUILDING PERMIT APPROVAL

___ FOUNDATION PERMIT APPROVAL

___ CERTIFICATE OF OCCUPANCY APPROVAL

___ ROUGH GRADING PERMIT APPROVAL

___ GRADING/PAVING PERMIT APPROVAL

___ OTHER _____ (SPECIFY)

DATE SUBMITTED: _____

BY: _____

Pre-Design Investigation
(Additions)

DATE 12 NOV '87

ADDRESS _____ ZONE ATLAS # K13

LEGAL DESCRIPTION _____

OWNER _____

ARCHITECT/ENGINEER _____

LOT SIZE _____

ZONING _____

PROPOSED DEVELOPMENT _____

RECEIVED
NOV 12 1987
HYDROLOGY SECTION

	YES	NO	NA	COMMENTS
FLOOD HAZARD AREA		B		
PART OF AN APPROVED REPORT		✓		
CONSTRUCTION PLANS ON MICRO-FILM		✓		
FIELD INSPECTION	✓			

COMMENTS:

MAJORITY OF SITE DRAINS WEST INTO DAKOTA THRU DRIVEPAD. ROOF DRAINS FOR ADDITION WILL BE CRITICAL DUE TO DISPLACEMENT. (SEE ME).!

Drain west toward alley.

DRAINAGE REQUIREMENTS: