

CITY OF ALBUQUERQUE
PLANNING DEPARTMENT
Hydrology Section
Predesign Meeting Conference Notes
DATE: 8-13-14

ZONE ATLAS PAGE: K18
DRAINAGE FILE: K180017
PROJECT SCOPE:

ADDRESS: 5901 Zuni PL SE

20,000 ± sq² bldg addition and possible
reconfiguration of parking lot

ATTENDANCE: Glenn Broughton, Curtis Cherne, Vyacheslav Prakhov

FINDINGS:

1. site is to manage the first flush
2. site can free discharge to the trunk
storm drain running through the site
3. most of site should drain to the storm drain

The undersigned agrees that the above findings are summarized accurately and are subject to change if further investigation reveals that they are not reasonable or that they are based on inaccurate information.

SIGNED: Curtis A. Cherne
NAME (PRINT): Curtis A. Cherne

SIGNED: Glenn Broughton
NAME (PRINT):

NOTE: PLEASE INCLUDE A COPY OF THIS SHEET WITH YOUR DRAINAGE SUBMITTAL