



Zone Atlas Page **K-18-Z**



EROSION CONTROL MEASURES:

THE CONTRACTOR SHALL BE HELD RESPONSIBLE FOR MANAGEMENT OF STORM RUNOFF DURING CONSTRUCTION; HE SHALL ENSURE THAT THE FOLLOWING MEASURES ARE TAKEN:

- ADJACENT PROPERTY SHALL BE PROTECTED AT ALL TIMES BY CONSTRUCTION OF BERMS, DIKES, SWALES, PONDS, AND OTHER TEMPORARY GRADING AS REQUIRED TO PREVENT STORM RUNOFF FROM LEAVING THE SUBJECT SITE AND ENTERING ADJACENT PROPERTIES.
- ADJACENT PUBLIC RIGHT-OF-WAYS SHALL BE PROTECTED AT ALL TIMES FROM STORM WATER RUNOFF FROM THE SUBJECT SITE. NO SEDIMENT BEARING WATER SHALL BE PERMITTED TO ENTER PUBLIC STREET RIGHT-OF-WAYS.
- THE CONTRACTOR SHALL IMMEDIATELY AND THOROUGHLY REMOVE ANY AND ALL SEDIMENT FROM PUBLIC STREETS THAT HAS BEEN ERODED FROM THE SUBJECT SITE AND DEPOSITED THEREON.

CONSTRUCTION NOTES:



- TWO (2) WORKING DAYS PRIOR TO ANY EXCAVATION, CONTRACTOR MUST CONTACT LINE LOCATING SERVICE AT 260-1990 FOR THE ACTUAL FIELD LOCATION OF THE EXISTING SURFACE OF SUB-SURFACE UTILITIES.
- PRIOR TO CONSTRUCTION, THE CONTRACTOR SHALL EXCAVATE AND VERIFY THE HORIZONTAL AND VERTICAL LOCATION(S) OF ALL POTENTIAL OBSTRUCTIONS; SHOULD A CONFLICT EXIST, THE CONTRACTOR SHALL NOTIFY THE ENGINEER SO THAT THE CONFLICT CAN BE RESOLVED WITH A MINIMUM OF DELAY.
- ALL WORK ON THIS PROJECT SHALL BE PERFORMED IN ACCORDANCE WITH ALL APPLICABLE FEDERAL, STATE, AND LOCAL LAWS, RULES AND REGULATIONS CONCERNING CONSTRUCTION SAFETY AND HEALTH.
- ALL CONSTRUCTION WITHIN PUBLIC STREET RIGHT-OF-WAY(S) SHALL BE PERFORMED IN ACCORDANCE WITH APPLICABLE CITY OF ALBUQUERQUE/BERNALILLO COUNTY STANDARDS AND PROCEDURES.

LEGEND:

- TOP OF CURB ELEVATION = 70'-06.18
- CURB FLOWLINE ELEVATION = 68'-05.50
- EXISTING SPOT ELEVATION = 82.2
- EXISTING CONTOUR ELEVATION = 11/4
- PROPOSED SPOT ELEVATION = 85.55
- PROPOSED CONTOUR ELEVATION = 11/4
- PROPOSED OR EXISTING CONCRETE SURFACE = [Symbol]
- EXISTING FENCE LINE = 11/4

GENERAL NOTES:


- NO PERIMETER BOUNDARY CORNERS HAVE BEEN FIELD ESTABLISHED PER THIS SURVEY OF THE SUBJECT PROPERTY.
- NO SEARCH HAS BEEN MADE FOR EASEMENTS OF RECORD OTHER THAN SHOWN HEREON.



A.1 PRECIPITATION ZONES

Bernalillo County's four precipitation zones are indicated in TABLE A-1 and on FIGURE A-1.

TABLE A-1. PRECIPITATION ZONES	
Zone	Location
1	West of the Rio Grande
2	Between the Rio Grande and San Mateo
3	Between San Mateo and Eubank, North of Interstate 40; and between San Mateo and the East boundary of Range 4 East, South of Interstate 40
4	East of Eubank, North of Interstate 40; and East of the East boundary of Range 4 East, South of Interstate 40



Where a watershed extends across a zone boundary, use the zone which contains the largest portion of the watershed.

DPM SECTION 22.2 - HYDROLOGY
January, 1993 Page A-4

TABLE A-4. LAND TREATMENTS	
Treatment	Land Condition
A	Soil uncompacted by human activity with 0 to 10 percent slopes. Native grasses, weeds and shrubs in typical densities with minimal disturbance to grading, groundcover and infiltration capacity. Croplands. Unlined arroyos.
B	Irrigated lawns, parks and golf courses with 0 to 10 percent slopes. Native grasses, weeds and shrubs, and soil uncompacted by human activity with slopes greater than 10 percent and less than 20 percent.
C	Soil compacted by human activity. Minimal vegetation. Unpaved parking, roads, trails. Most vacant lots. Gravel or rock on plastic (desert landscaping). Irrigated lawns and parks with slopes greater than 10 percent. Native grasses, weeds and shrubs, and soil uncompacted by human activity with slopes at 20 percent or greater. Native grass, weed and shrub areas with clay or clay loam soils and other soils of very low permeability as classified by SCS hydrologic Soil Group D.
D	Impervious areas, pavement and roofs.

Most watersheds contain a mix of land treatments. To determine proportional treatments, measure respective subareas. In lieu of specific measurements for treatment D, the areal percentages in TABLE A-5 may be employed.

Zone	TABLE A-4. PEAK DISCHARGE (cfs/min)			
	A	B	C	D
1	1.20 [0.00, 0.38]	2.00 [0.00, 0.76]	2.87 [0.07, 1.09]	4.97 [1.00, 2.88]
2	1.80 [0.00, 0.58]	2.88 [0.00, 0.88]	3.14 [0.00, 1.17]	4.70 [1.00, 3.14]
3	1.87 [0.00, 0.58]	2.80 [0.21, 1.10]	3.46 [0.29, 2.00]	6.02 [2.04, 3.88]
4	2.80 [0.00, 0.87]	2.88 [0.00, 1.40]	3.70 [1.00, 2.88]	6.38 [2.17, 3.87]

Zone	TABLE A-4. PEAK INTENSITY (RAIN at $t_p = 0.2$ hour)	
	Intensity [1-YR, 10-YR]	Intensity [1-YR, 10-YR]
1	4.70 [1.00, 3.14]	6.02 [2.04, 3.88]
2	6.02 [2.04, 3.88]	6.38 [2.31, 3.88]
3	6.38 [2.31, 3.88]	6.38 [2.31, 3.88]
4	6.38 [2.31, 3.88]	6.38 [2.31, 3.88]

315 SAN PEDRO DRIVE, N.E.

Drainage Comments:

As shown on the Vicinity Map hereon, the subject site is located on the West Side of San Pedro Avenue N.E. and North of Copper Avenue N.E., in the City of Albuquerque, New Mexico, (Zone Atlas Map "K-18-Z").

The subject site is presently an existing building with asphalt paved area.

The subject site, 1, does not lie within a designated floodplain (Re: F.E.M.A Panel 354 of 825), 2, does not accept offsite flows from adjacent properties, 3, free discharge of the proposed developed flows will not have an adverse affect to downstream properties, 4, does contribute flows (0.51 cfs) to the property west and adjacent to the subject site; these flows will continue to be accepted and passed through said site.

Calculations:

Site Area: 0.28
Zone: Three (3)
Peak Intensity: 5.38

Existing Conditions: (Total Site)			
Treatment	Area/Acre	Factor	Cfs
D	0.28	5.02	1.41



"Qp" = 1.41 Cfs

Existing Developed Conditions: (Flows to San Pedro N.E.)			
Treatment	Area/Acre	Factor	Cfs
D	0.18	5.02	0.90

"Qp" = 0.90 cfs

Legal Description: Lots 15 & 16, Block 16-A, Santilla Place Addition

Bench Mark Reference: ACS Station "5-K18B", Elevation 5290.330, Project T.B.M. as shown on plan hereon.



A PROPOSED PAVING PLAN FOR 315 SAN PEDRO DRIVE N.E. ALBUQUERQUE, NEW MEXICO MAY, 2006