

3/14/14

Met w/ Shawn Binger
to review past comments
& proposed resubmittal
Items for him to follow
up before Resubmittal

- ① Ensure water block near
mountable curb in Madira
- ② Provide typ. Section in
vacated alley. He'll propose
Crusher Fines to Cinnelli
to protect Nyopla stone
drains

Note - entire Site Now going
to SD-19 on Central

- ③ Try to Discharge the S. Roof
drain line to a depressed
Landscape area at west
end of Shops to Harvest &
set outfall pipe @ N side
of Landscaping Aug

④ Add a curb cut
in NE Loop to
Depressed NE Landscape
area.

- ⑤ Pumpster from to
San Sewer - shown to
get util. Plan from
Roger Cinelli.

AD 3/14/14