

From: [Wolfenbarger, Jeanne](#)
To: ["rob@r2architectural.com"](mailto:rob@r2architectural.com)
Subject: TCL Comments for Hillside Auto
Date: Thursday, October 09, 2014 4:56:34 PM

Rob, all of my comments are addressed from this past submittal, but after looking at the new 6-foot pedestrian pathway location, I still need the following:

1. Is the pedestrian 6-foot pathway asphalt? If so, label it as asphalt, and somehow indicate that it shall have a 2% maximum cross-slope. Also, provide striping delineating the walkway from the driving area south of the building.
2. You still have the words "Pedestrian Access" shown where the original 6-foot pathway was shown. Go ahead and delete this.

With this minor changes corrected, I can then approve the TCL. You can shoot me a pdf before making another trip down here to redeliver the two plans if you wish.

Jeanne

