

# CITY OF ALBUQUERQUE



January 11, 2019

Derek Kulach, Fiesta Auto group, derek\_kulach@fiestaautogroup.com  
Copy: Rick Gonzales, Hart Construction, rgonzales@hartconstruction.net

Site: Fiesta Kia-7400 Lomas Blvd NE

**Re: Drainage Ordinance (14-5-2-1) Violations for Erosion and Sediment Control**

Dear Mr. Kulach,

The following violation(s) were observed at today's inspection:

1. Sediment leaving the site and running down the gutter on Lomas Blvd.
2. Inadequate management of offsite flows.

Photos of the violations are shown below:

PO Box 1293

Albuquerque

New Mexico 87103

[www.cabq.gov](http://www.cabq.gov)



Sediment leaving site and entering Lomas Blvd.

# CITY OF ALBUQUERQUE



Photo of drive apron taken from Lomas Blvd.

PO Box 1293

Albuquerque

New Mexico 87103

[www.cabq.gov](http://www.cabq.gov)



Pipe from offsite basin discharging into the site.



# CITY OF ALBUQUERQUE



This area is adjacent to and uphill of the Vehicle Tracking Control pad.

PO Box 1293

Albuquerque

New Mexico 87103

[www.cabq.gov](http://www.cabq.gov)



The City deployed BMPs to help mitigate the amount of sediment entering Lomas Blvd.

# CITY OF ALBUQUERQUE

**Required mitigation:**

1. Prevent sediment from leaving the site and running down the gutter on Lomas Blvd.
2. Manage offsite flows so they don't flow into the dirt/mud then into Lomas Blvd.

Per the previous Violation letter, the City is assessing a fine of \$500. This fine is for one day.

Additional days may be added if the violation is not mitigated within seven days. In addition, your non-compliance may be reported to the New Mexico Environment Department, Surface Water Quality Bureau to aid in the determination if this issue is to be forwarded to the EPA.

PO Box 1293

If you have any questions, you can contact me at 924-3420, [ccherne@cabq.gov](mailto:ccherne@cabq.gov).

Albuquerque

Sincerely,

Curtis Cherne, P.E.  
Principal Engineer, Stormwater Quality  
Planning Dept.

New Mexico 87103

[www.cabq.gov](http://www.cabq.gov)