

CITY OF ALBUQUERQUE
PLANNING DEPARTMENT
DEVELOPMENT SERVICE / HYDROLOGY SECTION

DATE: 1-2-13
CONFERENCE RECAP

ZONE ATLAS PAGE NO: K201060
DRAINAGE FILE: —
ZONING: _____
DRB: _____
SUBJECT: Re development
STREET ADDRESS (IF KNOWN): 107 to 113 Euclid NE
SUBDIVISION NAME: _____

APPROVAL REQUESTED:

ATTENDANCE: Jim Dountas, Curtis Cherne

FINDINGS:

A portion of the lots should drain to
Central. Hinge line ~~to~~ $\frac{1}{3}$ to $\frac{1}{2}$ halfway
back from Euclid, depending on survey / existing grades

most likely the revised drainage ordinance will be
in effect by the end of March 2013. This will
require this site to retain / treat the first 0.44"
of the storm.

THE UNDERSIGNED AGREES THAT THE ABOVE FINDINGS ARE SUMMARIZED ACCURATELY AND ARE SUBJECT TO CHANGE
IF FURTHER INVESTIGATION REVEALS THAT THEY ARE NOT REASONABLE OR THAT THEY ARE BASED ON INACCURATE
INFORMATION.

SIGNED: Curtis A. Cherne
NAME (PRINT): Curtis A. Cherne

SIGNED: Jim Dountas
NAME (PRINT): Jim Dountas

NOTE PLEASE PROVIDE A COPY OF THIS RECAP WITH YOUR DRAINAGE SUBMITTAL.