

From: [Hughes, James D.](#)
To: "Fred Gorenz"; [Jesus Jurado \(jjurado@tlcplumbing.com\)](mailto:JesusJurado@tlcplumbing.com)
Cc: ["lbustillos@tlcplumbing.com"](mailto:lbustillos@tlcplumbing.com); [Sims, Timothy E.](#); ["Miriam Mitchell"](#)
Subject: RE: Winrock SWPPP - File # J19E058
Date: Tuesday, September 03, 2019 10:56:13 AM

Fred and Jesus,

Thanks for meeting with me on short notice last Thursday, and thanks for cleaning up the construction debris.

- Please include me on the inspection reports e-mail distribution list from Inspections Plus and provide copies of the previous reports.
- Please remember that the EPA's Construction General Permit (CGP) requires:
 - Construction and domestic waste must be placed in an acceptable container, and
 - Washout of paint, concrete, and stucco must be in a leak proof container, not on the dirt.

In accordance with the violation letter sent on 7/2/2019 fines will be assessed for repeat violations. Hopefully your SWPPP inspector knows the CGP, and will be able to steer you away from further violations.



DOUG HUGHES, P.E., CFM
principal engineer construction SWQ
o 505.924.3420
e jhughes@cabq.gov
cabq.gov/planning

From: Fred Gorenz [mailto:gorenz@goodmanrealty.com]
Sent: Thursday, August 29, 2019 1:49 PM
To: Jesus Jurado (jjurado@tlcplumbing.com); Hughes, James D.
Subject: RE: Winrock SWPPP

Hi Doug and Jesus

Doug's Ph number is 821-9313 and Jesus's number is 362-2070.

TLC is our General Contractor responsible for the overall SWPPP for the Owner (Goodman)

Thanks

Fred Gorenz

Senior Vice President, Director of Development

Goodman Realty Group

100 Sun Avenue NE, Suite 210

Albuquerque, NM 87109

Email: gorenz@goodmanrealty.com

Office: 505.881.0100 x225

Cell: 505.401.4650

www.goodmanrealty.com



This message and any attachments are intended only for the use of the addressee and may contain information that is privileged and confidential. If you are not the intended recipient, you are hereby notified that the dissemination of this communication, and any information contained within, is strictly prohibited. If you have received this communication in error, please notify the sender immediately by telephone or return email and delete this message and any attachments from your system. Thank you.

Consider the environment. Please do not print this email unless it is absolutely necessary to do so.

=====

This message has been analyzed by Deep Discovery Email Inspector.