



City of Albuquerque Stormwater Construction Site Inspection Report

General Information

Project Name:	Holiday Inn Express				
Location:	Copper Pointe				
Site Contact Name & Agency	Owen Johnson, Premier Hospitality	ESC File No.	K21E009H3		
	johnson.oj@gmail.com	NPDES Id. No.	NMR1001FF		
Inspection Date:	10/15/19	Start/End Time:	0950/1000hrs		
CoA Stormwater Inspector:	Timothy E. Sims				
Construction Phase:	site grading, stucco prep				
Type of Inspection:	☒ Regular	☐ Storm Event	☐ Post Storm Event >0.25"	☐ 311/Complaint	☐ Follow Up

Weather at time of inspection?	Clear	Temperature: ~	65*
Estimated date of last storm 0.25" or greater	10/4/2019		

Item Number	Deficiency/ Corrective Action		
1	Please provide the latest SWPPP self-inspection report		
2.1	Discharge off site? (Y/N)	No	
4	Self Inspection Reports	requested	Latest report Date: 8/9/2019

Notes:	

City of Albuquerque Stormwater Inspector Signature and date:
Contact information: Timothy E. Sims - (505) 803-6155
tsims@cabq.gov 10/15/19