

*Hydrology Section Planning Department*  
Brennon Williams, Interim Director

Timothy M. Keller, Mayor

December 3, 2019

Premier Hospitality V, LLC, [macllc702@msn.com](mailto:macllc702@msn.com) [hina@premierhospitality.net](mailto:hina@premierhospitality.net)

Site: Holiday Inn Express, 10500 Copper Ave, K21E009H3

**Re: Drainage Ordinance (14-5-2-1) Violations for Erosion and Sediment Control**

The following violations were observed at today's inspection.

1. Track-out in street.

See recent photos below.



**Required Mitigation:**

1. Implement additional track-out controls as necessary to ensure that sediment removal occurs prior to vehicle exit per CGP 2.2.4.c.
2. Where sediment has been tracked-out from your site onto paved roads, remove the deposited sediment by the end of the same business day in which the track-out occurs per CGP 2.2.4.d.

If the violations are not mitigated within 7 days, the property owner is subject to a fine of \$500/day per the City's Drainage Control Ordinance.

If you have any questions, you can contact me at 924-3420 or [jhughes@cabq.gov](mailto:jhughes@cabq.gov)

Sincerely,

*James D. Hughes*

James D. Hughes, P.E.  
Principal Engineer, Hydrology/Stormwater Quality  
Planning Dept.