

CITY OF ALBUQUERQUE



December 6, 2016

David Soule, P.E.
Rio Grande Engineering
9171 Glendale Ave NE
Albuquerque, NM 87122

**Re: Lomas Townhouses- 12844 Lomas Blvd NE
Erosion and Sediment Control Plan
Engineer's Stamp Date 12-2-16 (K22E057)**

Dear Mr. Soule,

Based upon the information provided in your submittal received 12-2-16 the above referenced plan is approved to be included in the SWPPP and to apply for an ESC Permit for grading and Building Permit with the following condition:

The "Wattle for Sewer Utility Cut" should also be used for the grading that will occur in the alley or the silt fence could be extended south.

PO Box 1293

Include a copy of the approved plan in the Building Permit set.

If you have any questions, you can contact me at 924-3420.

Albuquerque

Sincerely,

Curtis Cherne, P.E.
Principal Engineer, Stormwater Quality
Planning Dept.

New Mexico 87103

www.cabq.gov

C: email