From: Patz, Logan W.
To: "Roger Cinelli"
Subject: 12844 Lomas, Townhouses for Worque, K22D057
Date: Monday, November 07, 2016 10:34:00 AM

Hello Roger,

I was able to look over the TCL for the Lomas project. There is still one issue with the plans that can be addressed as a redline.
We need to show that the width of the ADA curb ramp in the detail is 6 feet to match the sidewalk.
If you are available to come in and make the change we can release the plans.

Thanks.

Logan Patz
Planning Department
Transportation Development
600 2nd St. NW, Suite 201
Albuquerque, NM 87102
505-924-3630