



CITY OF ALBUQUERQUE  
MUNICIPAL DEVELOPMENT DEPARTMENT  
ENGINEERING DIVISION



HYDROLOGY SECTION PROJ. NO. L-8 DATE: 9/28/84

PLANNING DIVISION NO. \_\_\_\_\_

CONFERENCE RECAP

SUBJECT: Far West Club  
Tracts 6 & 7 Town of Atrisco Grant Row 1

WHO

REPRESENTING

ATTENDANCE: Elvidio Digniz

Shaila Hall

Carlos Savilla

Billy Goolsby

FINDINGS: ① Raplot required to remove  
lotlines.

② Approved Drainage Plan required  
for Hydrology sign-off.

③ Discharge to be determined by  
analysis of downstream capacity -  
controlled discharge is appropriate to  
help relieve downstream flooding.

\* Please provide a copy of this recap w/submital

The undersigned agrees that the above findings are summarized accurately and are only subject to change if further investigation reveals that they are not reasonable or that they are based on inaccurate information.

SIGNED: Billy G. Goolsby

SIGNED: E. V. G.

TITLE: CE/Hydrology

TITLE: \_\_\_\_\_

DATE: 9/28/84

DATE: 9/28/84

**RESOURCE TECHNOLOGY, INCORPORATED**  
750 MARBLE AVENUE NE, SUITE 5  
ALBUQUERQUE, NEW MEXICO 87110

From. Elvidio Diniz

To: City Hydrology

Date: Dec. 7, 1984

Our Project No. 84-290

IF MATERIAL RECEIVED IS NOT AS LISTED,  
PLEASE NOTIFY US AT ONCE

Attn: Billy Goolsby

Re: Far West Club

WE ARE SENDING YOU

☒ ATTACHED      ☐ UNDER SEPARATE COVER VIA

☐ SHOP DRAWINGS      ☐ TRACINGS☒ PRINTS ☐ CATALOGS

☐ DOCUMENTS ☐ COPY OF LETTER

## □ SPECIFICATIONS

© 2006 The Authors  
Journal compilation © 2006 Blackwell Publishing Ltd

[illegible]

REMARKS \_\_\_\_\_

COPY TO \_\_\_\_\_

INFORMATION SHEET


PROJECT TITLE Far West Club TYPE OF SUBMITTAL Drainage + Grading  
 ZONE ATLAS PAGE NO. L-8/<sup>D8</sup> CITY ADDRESS 10205 Central Ave NW  
 LEGAL DESCRIPTION Tract A - Town of Arroyo Grande - Unit "A" Row one T10N  
Bernalillo City NM R2E  
 ENGINEERING FIRM Resource Technology CONTACT Elvidio Diniz  
 ADDRESS 7800 Marble NE #5 PHONE 266-3320  
 OWNER Antonio Bilotto CONTACT same  
 ADDRESS 7901 4th St NW PHONE 898-1418  
 ARCHITECT Roger Cinelli + Assoc. CONTACT R. Cinelli  
 ADDRESS 911 Fruit Ave. NW PHONE 842-6899  
 SURVEYOR Southwest Surveying CONTACT NOT AVAILABLE  
 ADDRESS 333 Lomas NE PHONE 247-1444  
 CONTRACTOR NOT AVAILABLE CONTACT —  
 ADDRESS — PHONE —

PRE-DESIGN MEETING:

☒ YES  
☐ NO  
☒ COPY OF CONFERENCE RECAP SHEET PROVIDED

PLEASE CHECK TYPE OF APPROVAL EXPECTED WITH THIS SUBMITTAL:

☐ SKETCH PLAT APPROVAL  
☐ PRELIMINARY PLAT APPROVAL  
☒ SITE DEVELOPMENT PLAN APPROVAL  
☐ FINAL PLAT APPROVAL  
☐ BUILDING PERMIT APPROVAL  
☐ CERTIFICATE OF OCCUPANCY APPROVAL  
☐ ROUGH GRADING PERMIT APPROVAL  
☐ GRADING/PAVING PERMIT APPROVAL  
☐ OTHER \_\_\_\_\_ (SPECIFY)



DATE SUBMITTED: 7 Dec 1984  
 BY: Elvidio Diniz

DRB# SV-84-29 — 11/06/84  
 EPC# 2-84-140 — 11/15/84



## City of Albuquerque

P.O. BOX 1293 ALBUQUERQUE, NEW MEXICO 87103

DESIGN HYDROLOGY SECTION  
123 Central NW, Albuquerque, NM 87102  
(505) 766-7644

January 10, 1985

Elvidio Diniz  
Resource Technology, Inc.  
7800 Marble Avenue, NE #5  
Albuquerque, New Mexico 87110

RE: DRAINAGE & GRADING PLAN FOR FAR WEST CLUB  
10205 CENTRAL AVENUE, NW (L-8/DB) RECEIVED DECEMBER 7, 1984

Mr. Diniz:

The referenced plan dated December 7, 1984, is approved.

Please attach a copy of this approved plan along with the appropriately approved "Drainage Facilities Within City Right-of-Way" document to the construction set prior to hydrology sign-off.

If I can be of further assistance, please call me at 766-7644.

Cordially,

Billy J. Goolsby, C.E.  
Design Hydrology Section

BJG/bsj

MUNICIPAL DEVELOPMENT DEPARTMENT

C. Dwayne Sheppard, P.E., City Engineer

ENGINEERING DIVISION

Telephone (505) 766-7467

AN EQUAL OPPORTUNITY EMPLOYER