

# CITY OF ALBUQUE

Planning Department  
Brennon Williams, Director



Mayor Timothy M. Keller

February 18, 2021  
Kelly Fetter  
E2RC  
439 South Hill Rd.  
Bernalillo NM, 87004

**Re: Mark Armijo Charter School Parking lot – 6900 Gonzales Rd SW  
Erosion and Sediment Control Plan  
Engineer's Stamp Date 1/4/2021 (L10E007A)**

Dear Mr. Fetter,

Based upon the information provided in your submittal received 2/01/2021, the above referenced ESC Plan is approved to be included in the SWPPP with the condition that:

1. The silt fence remain in place until the vegetation is established or gravel mulch is installed in accordance with CGP 2.2.14.

The EPA Notice of Intent (NOI) documentation has been reviewed and approved so this project is approved for Grading.

If you have any questions, you can contact me at 924-3420 or [jhughes@cabq.gov](mailto:jhughes@cabq.gov).

Sincerely,

*James D. Hughes*

James D. Hughes, P.E.  
Principal Engineer, Planning Dept.  
Development and Review Services