



City of Albuquerque

P.O. BOX 1293 ALBUQUERQUE, NEW MEXICO 87103

September 5, 2002

Amy Driscoll, PE
Mark Goodwin & Associates
P.O. Box 90606,
Albuquerque, NM 87199

Re: Bridge Crossing Subdivision Drainage Report
Engineer's Stamp dated 8-6-02, (L10/D22)

Dear Ms. Driscoll,

Based upon the information provided in your resubmittal dated 8-7-02, the above referenced report is approved for Work Order and Final Plat requirements.

If you have any questions, please contact me at 924-3986.

Sincerely,

Bradley L. Bingham, PE
Sr. Engineer, Planning Dept.
Development and Building Services

C: file



D. Mark Goodwin & Associates, P.A.
Consulting Engineers

P.O. BOX 90606, ALBUQUERQUE, NM 87199
(505) 828-2200 FAX 797-9539
e-mail: dmgs@swcp.com

August 6, 2002

Mr. Brad Bingham
City of Albuquerque
600 2nd Street SW
Albuquerque, NM 87103

**Re: Bridge Crossing Subdivision, (L10/D22)
Revised Grading and Drainage Plan**

Dear Mr. Bingham:


This letter is in response to your June 27, 2002 comments.

1. A complete, comprehensive, and bound report is included for your review.
2. Off-site flows (0.44 cfs) are coming towards our site from a swale to the northwest. The amount is small and will go around our perimeter wall back to the existing swale east of our property. Please see the Grading and Drainage Report.
3. The Hec-Ras has been redone and both standard and roll curb and gutter are shown on the plan. All calculations are included in the submittal.
4. The flow into the channel is discussed in the report.
5. The retaining wall to the west has been lowered. This will remove retaining wall through most of the subdivision. In addition, we believe having a slope in Basin B will deter people from walking through the strip. A public access easement is provided through the subdivision.


Please contact me if I can be of further assistance.

Sincerely,

MARK GOODWIN & ASSOCIATES, P.A.


Amy L. Driscoll, PE
Project Engineer

F:\Bridge\Brad2



DRAINAGE REPORT
for
BRIDGE CROSSING SUBDIVISION

Prepared By

Amy L. Driscoll, PE
Mark Goodwin & Associates, PA
P.O. Box 90606
Albuquerque, NM 87199



August 2002



RECEIVED
AUG 07 2006
HYDROLOGY S

MARK GOODWIN

& ASSOCIATES

dmg

##

ZONE ATLAS MAP

FINAL PL

<

