PUBLIC WORKS/HYDROLOGY
L12/D3

0000 0000 1299

L12/D3

25×10 32×10

0000 0000 1300

**City of Albuquerque**
P.O. BOX 1293 ALBUQUERQUE, NEW MEXICO 87103

DESIGN HYDROLOGY SECTION
123 Central NW, Albuquerque, NM 87102
(505) 766-7644

December 10, 1984

Mr. Doug May
Leedshill-Herkenhoff
P.O. Box 1217
Albuquerque, NM 87112

REF: DRAINAGE PLAN FOR ATRISCO WELL NUMBER 5 (L12-D3)

Dear Mr. May:

Based on the information provided on your October 4, 1984 and November 13, 1984 submittals, at this time, we are unable to process the above referenced drainage plan for approval until the items listed below have been addressed:

1. Information sheet with resubmittal designation.
2. Engineer's stamp with revision date.
3. We will need a clean copy without pen marks for our file.
4. Please show calculations for proposed ponds.
5. Legend showing proposed and existing development (Volume 2 tables 27.3a-27.3d).
6. Vicinity map must be included within the plan drawing. (DPM 22.7, Item 21).
7. Contours and spot elevations extending a minimum of 25' beyond property line. (DPM 22.7, Item 23C).



25×10 32×10

0000 0000 1301



If you have any questions or comments, please feel free to call me at 766-7644.

Sincerely yours,

Carlos A. Montoya

Carlos A. Montoya, PE
City/County Flood Plain Admin.

CAM:BJM:mrl

25×10 32×10

0000 0000 1302

LEEDSHILL - HERKENHOFF, INC.
Copper Square
P. O. Box 1217
Albuquerque, New Mexico 87103
(505) 247-0294

1519-1666.61-84

November 13, 1984

Mr. Carlos Montoya
Design Hydrology Section
Engineering Division MDD
City of Albuquerque
P.O. Box 1293
Albuquerque, N.M. 87103

RE: DRAINAGE PLAN FOR ATRISCO WELL NO. 5 (L12-D3)

Dear Mr. Montoya:

The following is our response to your November 5, 1984 letter:

1. Engineers Stamp should be dated 10-4-84.

2. The Reservoir and Pump Station are existing structures on the site. The roadway and well house will be new construction. The dashed lines indicate existing contours. The solid lines indicate finished contours.

3. There are no off-site flows.

If there are further questions, contact me at 247-0294.

Sincerely,

Doug May

DOUG MAY

jm

RECEIVED
NOV 13 1984
DESIGN HYDROLOGY
SECTION



25×10 32×10

0000 0000 1303

INFORMATION SHEET

PROJECT TITLE Atrisco Well No. 5 TYPE OF SUBMITTAL Drainage Plan

ZONE ATLAS PAGE NO. L-12 D3 update CITY ADDRESS 669 Atrisco Dr. S.W.

LEGAL DESCRIPTION

ENGINEERING FIRM Leedshill-Herkenhoff CONTACT Doug May

ADDRESS P.O. Box 1217 Albuquerque PHONE 247-0294

OWNER City of Albuquerque CONTACT Bill Otto Water Resources

ADDRESS PHONE 766-7100

ARCHITECT CONTACT

ADDRESS PHONE

SURVEYOR CONTACT

ADDRESS PHONE

CONTRACTOR CONTACT

ADDRESS PHONE

PRE-DESIGN MEETING:

X YES
___ NO
___ COPY OF CONFERENCE RECAP SHEET PROVIDED

PLEASE CHECK TYPE OF APPROVAL EXPECTED WITH THIS SUBMITTAL:

___ SKETCH PLAT APPROVAL
___ PRELIMINARY PLAT APPROVAL
___ SITE DEVELOPMENT PLAN APPROVAL
___ FINAL PLAT APPROVAL
___ BUILDING PERMIT APPROVAL
___ CERTIFICATE OF OCCUPANCY APPROVAL
___ ROUGH GRADING PERMIT APPROVAL
___ GRADING/PAVING PERMIT APPROVAL
x OTHER Drainage Plan (SPECIFY)

DATE SUBMITTED: ~~Oct. 4, 1984~~ Nov. 13, 1984

BY: Doug May

RECEIVED
NOV 13 1984
DESIGN HYDROLOGY SECTION

25×10 32×10

0000 0000 1304

**City of Albuquerque**
P.O. BOX 1293 ALBUQUERQUE, NEW MEXICO 87103

DESIGN HYDROLOGY SECTION
123 Central NW, Albuquerque, NM 87102
(505) 766-7644

November 5, 1984

Mr. Doug May
Leedshill-Herkenhoff
P.O. Box 1217
Albuquerque, NM 87112

REF: DRAINAGE PLAN FOR ATRISCO WELL NUMBER 5 (L12-D3) RECEIVED OCTOBER 4, 1984

Dear Mr. May:

I have reviewed the above referenced submittal and issue the following comments:

1. Please date the engineer's stamp.
2. Show what is existing and what is proposed.
3. Are there any off-site flows?

If you should have any questions, please contact me at 766-7644.

Sincerely yours,

Carlos A. Montoya

Carlos A. Montoya, PE
City/County Flood Plain Admin.

CAM:mrk



25×10 32×10

0000 0000 1305

INFORMATION SHEET

PROJECT TITLE Atrisco Well No. 5 TYPE OF SUBMITTAL Drainage Plan

ZONE ATLAS PAGE NO. L-12 D3 CITY ADDRESS 669 Atrisco Dr. S.W.

LEGAL DESCRIPTION

ENGINEERING FIRM Leedshill-Herkenhoff CONTACT Doug May

ADDRESS P.O. Box 1217 Albuquerque PHONE 247-0294

OWNER City of Albuquerque CONTACT Bill Otto Water Resources

ADDRESS PHONE 766-7100

ARCHITECT CONTACT

ADDRESS PHONE

SURVEYOR CONTACT

ADDRESS PHONE

CONTRACTOR CONTACT

ADDRESS PHONE

PRE-DESIGN MEETING:

X YES
___ NO
___ COPY OF CONFERENCE RECAP SHEET PROVIDED

PLEASE CHECK TYPE OF APPROVAL EXPECTED WITH THIS SUBMITTAL:

___ SKETCH PLAT APPROVAL
___ PRELIMINARY PLAT APPROVAL
___ SITE DEVELOPMENT PLAN APPROVAL
___ FINAL PLAT APPROVAL
___ BUILDING PERMIT APPROVAL
___ CERTIFICATE OF OCCUPANCY APPROVAL
___ ROUGH GRADING PERMIT APPROVAL
___ GRADING/PAVING PERMIT APPROVAL
X OTHER Drainage Plan (SPECIFY)

RECEIVED
OCT 04 1984
HYDROLOGY SECTION

DATE SUBMITTED: Oct. 4, 1984

BY: Doug May

25×10 32×10

0000 0000 1306

PLANS/PLATS ON FILE

FILE DESC: 42/D3

# PLANS/PLATS 1

25×10 32×10

0000 0000 1307