E. SAN JOSE ELEM.
SCHOOL

L14-D8

1 PLAN

31451

CITY OF ALBUQUERQUE
MUNICIPAL DEVELOPMENT DEPARTMENT
ENGINEERING DIVISION

HYDROLOGY SECTION PROJ. NO. _____ DATE: 11/23/83

PLANNING DIVISION NO. _____

CONFERENCE RECAP

SUBJECT: East San Jose Elementary (L14)

| | WHO | REPRESENTING |
|---|---|---|
| ATTENDANCE: | Jeff Mortensen | |
| | Fred J. Aguirre | |

FINDINGS:

1. Controlled discharge not required; however further development on-site may require a comprehensive drainage plan

2. Drainage Plan required for the proposed development

RECEIVED
JAN 10 1984
ENGINEERING

The undersigned agrees that the above findings are summarized accurately and are subject to change if further investigation reveals that they are not reasonable or that they are based on inaccurate information.

| | |
|---|---|
| SIGNED: Fred Aguirre | SIGNED: Jeffrey G. Mortensen |
| TITLE: | TITLE: PROJECT ENGINEER |
| DATE: 11/23/83 | DATE: 11/23/83 |

INFORMATION SHEET

PROJECT TITLE E. San Jose Elem. School TYPE OF SUBMITTAL GRADING & DRAINAGE PLAN

ZONE ATLAS PAGE NO. L-14 98 CITY ADDRESS 415 Thaxton Ave SE.

LEGAL DESCRIPTION ?

ENGINEERING FIRM Tom Mann & Assoc. CONTACT Jeffrey G. Mortensen

ADDRESS 811 Dallas NE PHONE 265-5611

OWNER APS CONTACT Bill McMillin

ADDRESS _____ PHONE 242-5865

ARCHITECT Dekker & Assoc CONTACT Dale Dekker

ADDRESS _____ PHONE 884-3689

SURVEYOR Tom Mann CONTACT J.G. Mortensen

ADDRESS _____ PHONE _____

CONTRACTOR Not Known CONTACT _____

ADDRESS _____ PHONE _____

PRE-DESIGN MEETING:

X YES
___ NO
X COPY OF CONFERENCE RECAP SHEET PROVIDED

PLEASE CHECK TYPE OF APPROVAL EXPECTED WITH THIS SUBMITTAL:

___ SKETCH PLAT APPROVAL
___ PRELIMINARY PLAT APPROVAL
___ SITE DEVELOPMENT PLAN APPROVAL
___ FINAL PLAT APPROVAL
X BUILDING PERMIT APPROVAL
___ CERTIFICATE OF OCCUPANCY APPROVAL
___ ROUGH GRADING PERMIT APPROVAL
___ GRADING/PAVING PERMIT APPROVAL
___ OTHER _____ (SPECIFY)

RECEIVED
JAN 10 1984
ENGINEERING

DATE SUBMITTED: 01/09/84

BY: J.G. Mortensen

**City of Albuquerque**
P.O. BOX 1293 ALBUQUERQUE, NEW MEXICO 87103

FILE COPY

January 17, 1984

Mr. Jeffrey G. Mortensen
Tom Mann & Associates, Inc.
811 Dallas NE
Albuquerque, NM 87110

REF: EAST SAN JOSE ELEMENTARY SCHOOL (L14-D8)

Dear Mr. Mortensen:

Based on the information provided on your January 10, 1984 submittal, the above referenced drainage plan is approved. It may be beneficial to route the downspouts under the concrete walk to eliminate the possibility of any injuries that may occur during any icing.

If you have any questions, please feel free to call me at 766-7644.

Sincerely,

Bernie J. Montoya

Bernie J. Montoya
Hydrologic Engineering Tech.
C.E.

BJM:mrk

C INFORMATION SHEET C 31451

PROJECT TITLE E. San Jose TYPE OF SUBMITTAL Revised Plan

ZONE ATLAS PAGE NO. L-14 D6 CITY ADDRESS _____

LEGAL DESCRIPTION _____

ENGINEERING FIRM Tom Mann & Assoc. CONTACT Jeffrey G. Mortensen

ADDRESS 811 Dallas NE PHONE 265-5611

OWNER APS CONTACT Bill McMillin

ADDRESS _____ PHONE 242-5865

ARCHITECT Dekker & Assoc CONTACT Dale Dekker

ADDRESS _____ PHONE 247-2888

SURVEYOR Tom Mann CONTACT J.G. Mortensen

ADDRESS _____ PHONE _____

CONTRACTOR Not Known CONTACT _____

ADDRESS _____ PHONE _____

PRE-DESIGN MEETING:

✓ YES
___ NO Past Approval L14 - D8
✓ COPY OF ~~CONFERENCE RECAP SHEET~~ PROVIDED

PLEASE CHECK TYPE OF APPROVAL EXPECTED WITH THIS SUBMITTAL:

___ SKETCH PLAT APPROVAL
___ PRELIMINARY PLAT APPROVAL
___ SITE DEVELOPMENT PLAN APPROVAL
___ FINAL PLAT APPROVAL
✓ BUILDING PERMIT APPROVAL
___ CERTIFICATE OF OCCUPANCY APPROVAL
___ ROUGH GRADING PERMIT APPROVAL
___ GRADING/PAVING PERMIT APPROVAL
___ OTHER _____ (SPECIFY)

DATE SUBMITTED: 3/13/84

BY: J.G. Mortensen

RECEIVED
MAR 14 1984
HYDROLOGY SECTION

# City of Albuquerque

P.O. BOX 1293 ALBUQUERQUE, NEW MEXICO 87103

**DESIGN HYDROLOGY SECTION**
**123 Central NW, Albuquerque, NM 87102**
**(505) 766-7644**


April 24, 1984

Mr. Jeff Mortensen
Tom Mann & Associates
811 Dallas NE
Albuquerque, NM 87110

REF: EAST SAN JOSE ELEMENTARY SCHOOL (L14-D8)

Dear Jeff:

Based on the information provided on your March 13, 1984 resubmittal, the above revised drainage plan is approved.

If you have any questions, please feel free to call me at 766-7644.

Sincerely,

Bernie J. Montoya

Bernie J. Montoya
Hydrologic Engineering Tech. CE

BJM:mrk