

CITY OF ALBUQUERQUE



August 28, 2017

Thomas Johnston PE, PS
TGC Engineering, Inc.
330 Louisiana Blvd NE
Albuquerque, NM 87108

**Re: Sonic 8th and Bridge
Erosion and Sediment Control Plan
Engineer's Stamp Date 6-28-17 (L14E025A)**

Dear Mr. Johnston,

Based upon the information provided in your submittal received 7-17-17 and 8-23-17, the above referenced plan is not approved to be included in the SWPPP and to apply for an ESC Permit for grading and Building Permit until the following comments are addressed:

1. Provide existing and proposed topography.
2. Provide the drainage outfall location(s).
3. Provide a detail for each BMP proposed.

If you have any questions, you can contact me at 924-3420.

Sincerely,

Curtis Cherne, P.E.
Principal Engineer, Stormwater Quality
Planning Dept.

PO Box 1293

Albuquerque

New Mexico 87103

www.cabq.gov