

DRAINAGE INFORMATION SHEET

PROJECT TITLE Odor Control Station#29 ZONE ATLAS/DRAINAGE FILE # I-14 / D30

LEGAL DESCRIPTION: Municipal Addition No. 6 Replat of Tract 6A

CITY ADDRESS: P.O. Box 1293, Albuquerque, NM 87103

ENGINEERING FIRM: Camp Dresser & McKee CONTACT: Anne Couture

ADDRESS: 2400 Louisiana Blvd. NE, Suite 740 PHONE: 881-3077

OWNER: City of Albuquerque CONTACT: Mike Wimberly

ADDRESS: P.O. Box 1293 PHONE: 873-6274

ARCHITECT: _____ CONTACT: _____

ADDRESS: _____ PHONE: _____

SURVEYOR: Santiago Romero & Assoc. CONTACT: Santiago Romero

ADDRESS: 6139 Edith Blvd. PHONE: 345-2733

CONTRACTOR: _____ CONTACT: _____

ADDRESS: _____ PHONE: _____


PRE-DESIGN MEETING:

☐ YES DRB NO. _____

☐ NO EPC NO. _____

☐ COPY OF CONFERENCE HYDROLOGY SECTION PROJECT NO. _____

RECAP SHEET PROVIDED



TYPE OF SUBMITTAL:

☐ DRAINAGE REPORT ☐ SECTOR PLAN APPROVAL

☐ DRAINAGE PLAN ☐ SKETCH PLAT APPROVAL

☒ CONCEPTUAL GRADING & DRAIN PLAN ☐ PRELIMINARY PLAT APPROVAL

☐ GRADING PLAN ☒ SITE DEVELOPMENT PLAN APPROVAL

☐ EROSION CONTROL PLAN ☐ FINAL PLAT APPROVAL

☐ ENGINEER'S CERTIFICATION ☐ BUILDING PERMIT APPROVAL

☐ FOUNDATION PERMIT APPROVAL


☐ CERTIFICATE OF OCCUPANCY APPROVAL

☐ ROUGH GRADING PERMIT APPROVAL

DATE SUBMITTED: 12/6/89 ☐ GRADING/PAVING PERMIT APPROVAL

BY: Anne M. Couture ☐ OTHER _____ (SPECIFY)

FILE COPY



City of Albuquerque

P.O. BOX 1293 ALBUQUERQUE, NEW MEXICO 87103

KEN SCHULTZ
MAYOR

CLARENCE V. LITHGOW

CHIEF
ADMINISTRATIVE OFFICER

DAN WEAKS

DEPUTY CAO
PUBLIC SERVICES

FRED E. MONDRAGON

DEPUTY CAO
DEVELOPMENT & ENTERPRISE SERVICES

RAY R. BACA

DEPUTY CAO
PUBLIC SAFETY

July 20, 1989

Ann Couture
CDM
2400 Louisiana Boulevard, NE Building #5
Albuquerque, New Mexico 87109

RE: FIELD INSPECTION FOR ODOR CONTROL STATIONS 4, 19, & 29
(L-14)

L14/030

Dear Mrs. Couture:

Field inspections have been made of the referenced sites, and I forward the following comments.

Odor Control Station 4

The new structure is less than 500 square feet in area. Therefore, a drainage plan will not be required. The flows from the site need to be directed to 12th Street.

Odor Control Station 19

This site will not need a drainage plan. The site will have minimum impact on downstream facilities. Flows from the site need to be directed to John Street.

Also, off-site flows cannot be blocked but must be conveyed through the property.

Odor Control Station 29

We will require a drainage plan for this site. Downstream capacity is a problem for this site.


Should you have any questions, please feel free to call me at 768-2650.

Cordially,

Carlos A. Montoya, P.E.
City/County Floodplain Administrator


CAM/bsj
(WP+1146)

TEMP. PARKING
FOR EXISTING
FACILITIES



GRADING & DRAINAGE

SCALE: 1" = 10'-0"



CITY OF ALBUQUERQUE PUBLIC WORKS DEPARTMENT ENGINEERING GROUP					
TITLE: ODOR CONTROL STATION NO. 29					
GRADING & DRAINAGE					
APPROVALS	ENGINEER	DATE	APPROVALS	ENGINEER	DATE
D/R Chair					
Trans. Dev					
Utility Dev					
DRAWING NO.		MAP NO. L-14		SHEET 4 OF 4	

ENGINEER'S SEAL		SURVEY INFORMATION		BENCH MARKS		AS BUILT INFORMATION	
		FIELD NOTES				CONTRACT NO.	
		NO. BY DATE				WORK STARTED BY DATE	
						WORK STOPPED BY DATE	
						FIELD ACCEPTANCE BY DATE	
						FIELD REVISION BY DATE	
						DRAWING CORRECTED BY DATE	
						MICRO-FILM INFORMATION	
						RECORDED BY DATE	
						NO	