


Pre-Design Investigation
(Additions)



DATE 7/7/89

ADDRESS John St & Stadium Blvd. ZONE ATLAS # L-14 | D31

LEGAL DESCRIPTION All of Lot 21, Block 2, Replat of Block 2 of New Eng Fruit Addition

OWNER City of Albuquerque

ARCHITECT/ENGINEER Camp Dresser & McKee (881-3077 - Anne)

LOT SIZE _____

ZONING _____

PROPOSED DEVELOPMENT Add New structure

	YES	NO	NA	COMMENTS
FLOOD HAZARD AREA		✓		Zone C
PART OF AN APPROVED REPORT				
CONSTRUCTION PLANS ON MICRO-FILM				
FIELD INSPECTION				

COMMENTS:

DRAINAGE REQUIREMENTS:

Will not need a drainage plan
see letter. CAM 7-17-89.

FILE COPY

City of Albuquerque

P.O. BOX 1293 ALBUQUERQUE, NEW MEXICO 87103



KEN SCHULTZ
MAYOR

CLARENCE V. LITHGOW
CHIEF
ADMINISTRATIVE OFFICER

DAN WEAKS
DEPUTY CAO
PUBLIC SERVICES

FRED E. MONDRAGON
DEPUTY CAO
DEVELOPMENT & ENTERPRISE SERVICES

RAY R. BACA
DEPUTY CAO
PUBLIC SAFETY

July 20, 1989

Ann Couture
CDM
2400 Louisiana Boulevard, NE Building #5
Albuquerque, New Mexico 87109

L141031

RE: FIELD INSPECTION FOR ODOR CONTROL STATIONS 4, 19, & 29
(L-14)

Dear Mrs. Couture:

Field inspections have been made of the referenced sites, and I forward the following comments.

Odor Control Station 4

The new structure is less than 500 square feet in area. Therefore, a drainage plan will not be required. The flows from the site need to be directed to 12th Street.

Odor Control Station 19

This site will not need a drainage plan. The site will have minimum impact on downstream facilities. Flows from the site need to be directed to John Street.

Also, off-site flows cannot be blocked but must be conveyed through the property.

Odor Control Station 29


We will require a drainage plan for this site. Downstream capacity is a problem for this site.

Should you have any questions, please feel free to call me at 768-2650.

Cordially,

Carlos A. Montoya, P.E.
City/County Floodplain Administrator

CAM/bsj
(WP+1146)



CITY OF ALBUQUERQUE PUBLIC WORKS DEPARTMENT ENGINEERING GROUP		ENGINEER'S SEAL		SURVEY INFORMATION FIELD NOTES		BENCH MARKS		AS BUILT INFORMATION	
TITLE: ODDOR CONTROL STATION NO. 19 GRADING & DRAINAGE		NO. DATE REMARKS BY		NO. BY DATE		CONTRACTOR		WORK STARTED BY DATE	
APPROVALS D.R.C. Chair Trans. Dev. Utility Dev.		REVISIONS DESIGN		DESIGNED BY DATE DRAWN BY DATE CHECKED BY DATE		INSPECTOR'S ACCEPTANCE BY DATE		FIELD VERIFICATION BY DATE DRAWINGS CORRECTED BY DATE	
JUL 07 1989		MICRO-FILM INFORMATION		RECORDED BY DATE		NO.		DATE	
DRAWING NO. L-14		MAP NO. L-14		SHEET 4 OF 4		DATE		DATE	