Hello Doug,

There are four items that need to be addressed at the site listed above before we can issue a CO.

- 1. The Handicap Ramp going to the front needs to meet ADA requirements. The concrete before the ramp appears to be out of compliance.
- The ADA accessible parking sign must have the required language per (66-7-352.4C NMSA 1978) "Violators Are Subject to a Fine and/or Towing."
- 3. The motor cycle space needs to be identified.
- 4. Please remove all construction debris from the construction site. (The old stairs should be removed)

Please contact me if you have any questions.

Thank you.

Logan Patz

Planning Department Transportation Development 600 2nd St. NW, Suite 201 Albuquerque, NM 87102 505-924-3630