City of Albuquerque Stormwater Construction Site Inspection Report

General Information

ESC File No.	L14E068	Project Name:	El Mezquite Market Renovation
NPDES Id. No.	NMR100782	Location:	1306 Broadway Blvd SE

10/8/2025	Owner	Contractor
Operator	Bermudez Bros LLC	Mountain Side Contractors LLC
Contact name & title	Sergio Bermudez	Aldo Ornelas
e-mail	sergiob@elmezquitemarket.net	mountainsidecontractors@gmail.com
Contact Phone #	505-975-5175	505-227-1782

COA Inspector	**Chancellor English**	Start/End Time:	1045am
Construction Phase:	Demolition		

Type of Inspection:	Regular	Storm Event	Post Storm Event >0.25"	311/Complaint	Follow Up

Weather at time of inspection?	Cloudy	Temperature: ~	75
Estimated date of last storm 0.25" or greater		11/7/2024	

Item Number	Deficiency/ Corrective Action			
1	SWPPP - Your inspection reports were not available during the inspection in violation of CGP Part 4.7.3. The contractor's NOI was missing from the SWPPP in violation of CGP Part 7.2.11. Required mitigation: You must keep a copy of all inspection reports at the site or at an easily accessible location so that they can be made available at the time of an on-site inspection per CGP Part 4.7.3. Once you are authorized for CGP coverage, you must include a copy of your NOI submitted to the EPA per CGP Part 7.2.11.a.			
2.1	Discharge off site? (Y/N)	no		
4	Self Inspection Reports	No	Latest report Date:	N/A

Notes:
The gate lock combo is 0715.
The SWPPP is in a display case in the main building.

City of Albuquerque Stormwater Inspector Signature and date: 10/8/2025

Contact information: Chancellor English (505) 924-3325

cenglish@cabq.gov

Chancellor English