

## City of Albuquerque Stormwater Construction Site Inspection Report

ESC File No.   L15E057_UNM   Project Name:   Alumni Drive Extension   NMR1006T2 LEW   Location:   Alumni Dr and Gibson SE	General Information								
A/23/2025   Owner	ESC File No.					Alumni Drive Extension			
Operator University of New Mexico Compass Engineering & Construction Services, LLC Contact name & title Teresa Costantinidis William Lucero e-mail keelie@unm.edu Willi@compasssmm.com Contact Phone # 505-227-7520 505-221-6003  COA Inspector Chancellor English Start/End Time: 2pm  Construction Phase: Pre-paving  Type of Inspection: Regular Storm Event Post Storm Event > 0.25" 311/Complaint Follow Up  Weather at time of inspection? Clear Temperature: 75  Estimated date of last storm 0.25" or greater 4/20/2025  Item Number  1 The Erosion and Sediment Control Permit was not posted at the site in violation of CGP Part 1.5. Required mitigation: You must post a sign or other notice of your permit coverage at a safe, publicly accessible location in close proximity to the construction site per CGP Part 1.5.  2 According to the superintendent of the site, there have been no self-inspections performed during construction in violation of City Ordinance 14-5-2-11 and CGP Part 4.2. Required mitigation: At a minimum, a routine self-inspection is required to review the project for compliance with the Construction General Permit once every 14 days and after any precipitation event of 1/4 inch or greater until the site construction has been completed and the site determined as stabilized by the City per City Ordinance 14-5-2-11 and CGP Part 4.2.2.  3 The silt fence and mulch socks were not installed according to the ESC Plan approved by the City in violation of CGP Part 2.1.3. Required mitigation: Complete installation of stormwater controls by the time each phase of construction activities has begun per CGP Part 2.1.3.	NPDES Id. No.	NMR1006	NMR1006TZ LEW Loc			Alumni Dr and Gibson SE			
Contact name & title	4/2	3/2025	Owner						
Regular   Sobstance   Sobsta	Operator								
Contact Phone # 505-227-7520   505-221-6003    COA Inspector   Chancellor English   Start/End Time:   2pm    Construction Phase:   Pre-paving   Type of Inspection:   Regular   Storm Event   Post Storm Event >0.25"   311/Complaint   Follow Up   Weather at time of inspection?   Clear   Temperature: ~ 75  Estimated date of last storm 0.25" or greater   4/20/2025    Item   Number   Deficiency/ Corrective Action    1	Contact na	Contact name & title		Teresa Costantinidis			William Lucero		
COA Inspector  Construction Phase: Type of Inspection:  Regular   Storm Event   Post Storm Event > 0.25"   311/Complaint   Follow Up  Weather at time of inspection?   Clear   Temperature: ~ 75  Estimated date of last storm 0.25" or greater   4/20/2025  Item Number   Deficiency/ Corrective Action    The Erosion and Sediment Control Permit was not posted at the site in violation of CGP Part 1.5. Required mitigation: You must post a sign or other notice of your permit coverage at a safe, publicly accessible location in close proximity to the construction site per CGP Part 1.5.  According to the superintendent of the site, there have been no self-inspections performed during construction in violation of City Ordinance 14-5-2-11 and CGP Part 4.2. Required mitigation: At a minimum, a routine self-inspection is required to review the project for compliance with the Construction General Permit once every 14 days and after any precipitation event of 1/4 inch or greater until the site construction has been completed and the site determined as stabilized by the City per City Ordinance 14-5-2-11 and CGP Part 4.2.2.  The silt fence and mulch socks were not installed according to the ESC Plan approved by the City in violation of CGP Part 2.1.3. Required mitigation: Complete installation of stormwater controls by the time each phase of construction activities has begun per CGP Part 2.1.3.  Discharge off site? (Y/N) no		e-mail							
Construction Phase: Type of Inspection: Regular Storm Event Post Storm Event > 0.25" Regular Storm Event > 0.25" Regular Storm Event > 0.25" Regular Regular Storm Event > 0.25" Regular Regul	Contact Phone #		505-227-7520			505-221-6003			
Type of Inspection:   Regular   Storm Event   Post Storm Event > 0.25"   311/Complaint   Follow Up  Weather at time of inspection?   Clear   Temperature: ~ 75  Estimated date of last storm 0.25" or greater   4/20/2025  Item   Deficiency/ Corrective Action    In   The Erosion and Sediment Control Permit was not posted at the site in violation of CGP Part 1.5.  Required mitigation: You must post a sign or other notice of your permit coverage at a safe, publicly accessible location in close proximity to the construction site per CGP Part 1.5.  According to the superintendent of the site, there have been no self-inspections performed during construction in violation of City Ordinance 14-5-2-11 and CGP Part 4.2. Required mitigation: At a minimum, a routine self-inspection is required to review the project for compliance with the Construction General Permit once every 14 days and after any precipitation event of 1/4 inch or greater until the site construction has been completed and the site determined as stabilized by the City per City Ordinance 14-5-2-11 and CGP Part 4.2.2.  The silt fence and mulch socks were not installed according to the ESC Plan approved by the City in violation of CGP Part 2.1.3. Required mitigation: Complete installation of stormwater controls by the time each phase of construction activities has begun per CGP Part 2.1.3.	COA Inspector						•		
Weather at time of inspection? Clear Temperature: ~ 75  Estimated date of last storm 0.25" or greater 4/20/2025  Item Number  The Erosion and Sediment Control Permit was not posted at the site in violation of CGP Part 1.5. Required mitigation: You must post a sign or other notice of your permit coverage at a safe, publicly accessible location in close proximity to the construction site per CGP Part 1.5.  According to the superintendent of the site, there have been no self-inspections performed during construction in violation of City Ordinance 14-5-2-11 and CGP Part 4.2. Required mitigation: At a minimum, a routine self-inspection is required to review the project for compliance with the Construction General Permit once every 14 days and after any precipitation event of 1/4 inch or greater until the site construction has been completed and the site determined as stabilized by the City per City Ordinance 14-5-2-11 and CGP Part 4.2.2.  The silt fence and mulch socks were not installed according to the ESC Plan approved by the City in violation of CGP Part 2.1.3. Required mitigation: Complete installation of stormwater controls by the time each phase of construction activities has begun per CGP Part 2.1.3.  Discharge off site? (Y/N) no	Construction Phase:								
Item Number  The Erosion and Sediment Control Permit was not posted at the site in violation of CGP Part 1.5. Required mitigation: You must post a sign or other notice of your permit coverage at a safe, publicly accessible location in close proximity to the construction site per CGP Part 1.5.  According to the superintendent of the site, there have been no self-inspections performed during construction in violation of City Ordinance 14-5-2-11 and CGP Part 4.2. Required mitigation: At a minimum, a routine self-inspection is required to review the project for compliance with the Construction General Permit once every 14 days and after any precipitation event of 1/4 inch or greater until the site construction has been completed and the site determined as stabilized by the City per City Ordinance 14-5-2-11 and CGP Part 4.2.2.  The silt fence and mulch socks were not installed according to the ESC Plan approved by the City in violation of CGP Part 2.1.3. Required mitigation: Complete installation of stormwater controls by the time each phase of construction activities has begun per CGP Part 2.1.3.  Discharge off site? (Y/N) no	Type of Inspection:		Regular   Storm Event   Post Storm						
Item Number  The Erosion and Sediment Control Permit was not posted at the site in violation of CGP Part 1.5.  Required mitigation: You must post a sign or other notice of your permit coverage at a safe, publicly accessible location in close proximity to the construction site per CGP Part 1.5.  According to the superintendent of the site, there have been no self-inspections performed during construction in violation of City Ordinance 14-5-2-11 and CGP Part 4.2. Required mitigation: At a minimum, a routine self-inspection is required to review the project for compliance with the Construction General Permit once every 14 days and after any precipitation event of 1/4 inch or greater until the site construction has been completed and the site determined as stabilized by the City per City Ordinance 14-5-2-11 and CGP Part 4.2.2.  The silt fence and mulch socks were not installed according to the ESC Plan approved by the City in violation of CGP Part 2.1.3. Required mitigation: Complete installation of stormwater controls by the time each phase of construction activities has begun per CGP Part 2.1.3.  Discharge off site? (Y/N) no	Weather at time of i		nspection?	Clea	ear Temperature: ~ 75		75		
Number  The Erosion and Sediment Control Permit was not posted at the site in violation of CGP Part 1.5. Required mitigation: You must post a sign or other notice of your permit coverage at a safe, publicly accessible location in close proximity to the construction site per CGP Part 1.5.  According to the superintendent of the site, there have been no self-inspections performed during construction in violation of City Ordinance 14-5-2-11 and CGP Part 4.2. Required mitigation: At a minimum, a routine self-inspection is required to review the project for compliance with the Construction General Permit once every 14 days and after any precipitation event of 1/4 inch or greater until the site construction has been completed and the site determined as stabilized by the City per City Ordinance 14-5-2-11 and CGP Part 4.2.2.  The silt fence and mulch socks were not installed according to the ESC Plan approved by the City in violation of CGP Part 2.1.3. Required mitigation: Complete installation of stormwater controls by the time each phase of construction activities has begun per CGP Part 2.1.3.  Discharge off site? (Y/N) no	Estimated date of last storm 0.25" or greater 4/20/2025								
Number  The Erosion and Sediment Control Permit was not posted at the site in violation of CGP Part 1.5. Required mitigation: You must post a sign or other notice of your permit coverage at a safe, publicly accessible location in close proximity to the construction site per CGP Part 1.5.  According to the superintendent of the site, there have been no self-inspections performed during construction in violation of City Ordinance 14-5-2-11 and CGP Part 4.2. Required mitigation: At a minimum, a routine self-inspection is required to review the project for compliance with the Construction General Permit once every 14 days and after any precipitation event of 1/4 inch or greater until the site construction has been completed and the site determined as stabilized by the City per City Ordinance 14-5-2-11 and CGP Part 4.2.2.  The silt fence and mulch socks were not installed according to the ESC Plan approved by the City in violation of CGP Part 2.1.3. Required mitigation: Complete installation of stormwater controls by the time each phase of construction activities has begun per CGP Part 2.1.3.  Discharge off site? (Y/N) no	Item								
The Erosion and Sediment Control Permit was not posted at the site in violation of CGP Part 1.5.  Required mitigation: You must post a sign or other notice of your permit coverage at a safe, publicly accessible location in close proximity to the construction site per CGP Part 1.5.  According to the superintendent of the site, there have been no self-inspections performed during construction in violation of City Ordinance 14-5-2-11 and CGP Part 4.2. Required mitigation: At a minimum, a routine self-inspection is required to review the project for compliance with the Construction General Permit once every 14 days and after any precipitation event of 1/4 inch or greater until the site construction has been completed and the site determined as stabilized by the City per City Ordinance 14-5-2-11 and CGP Part 4.2.2.  The silt fence and mulch socks were not installed according to the ESC Plan approved by the City in violation of CGP Part 2.1.3. Required mitigation: Complete installation of stormwater controls by the time each phase of construction activities has begun per CGP Part 2.1.3.  Discharge off site? (Y/N) no		Deficiency/ Corrective Action							
Required mitigation: You must post a sign or other notice of your permit coverage at a safe, publicly accessible location in close proximity to the construction site per CGP Part 1.5.  2 According to the superintendent of the site, there have been no self-inspections performed during construction in violation of City Ordinance 14-5-2-11 and CGP Part 4.2. Required mitigation: At a minimum, a routine self-inspection is required to review the project for compliance with the Construction General Permit once every 14 days and after any precipitation event of 1/4 inch or greater until the site construction has been completed and the site determined as stabilized by the City per City Ordinance 14-5-2-11 and CGP Part 4.2.2.  3 The silt fence and mulch socks were not installed according to the ESC Plan approved by the City in violation of CGP Part 2.1.3. Required mitigation: Complete installation of stormwater controls by the time each phase of construction activities has begun per CGP Part 2.1.3.  2.1 Discharge off site? (Y/N) NO							<u> </u>		
accessible location in close proximity to the construction site per CGP Part 1.5.  2 According to the superintendent of the site, there have been no self-inspections performed during construction in violation of City Ordinance 14-5-2-11 and CGP Part 4.2. Required mitigation: At a minimum, a routine self-inspection is required to review the project for compliance with the Construction General Permit once every 14 days and after any precipitation event of 1/4 inch or greater until the site construction has been completed and the site determined as stabilized by the City per City Ordinance 14-5-2-11 and CGP Part 4.2.2.  3 The silt fence and mulch socks were not installed according to the ESC Plan approved by the City in violation of CGP Part 2.1.3. Required mitigation: Complete installation of stormwater controls by the time each phase of construction activities has begun per CGP Part 2.1.3.  2.1 Discharge off site? (Y/N) NO	1	The Erosion and Sediment Control Permit was not posted at the site in violation of CGP Part 1.5.							
According to the superintendent of the site, there have been no self-inspections performed during construction in violation of City Ordinance 14-5-2-11 and CGP Part 4.2. Required mitigation: At a minimum, a routine self-inspection is required to review the project for compliance with the Construction General Permit once every 14 days and after any precipitation event of 1/4 inch or greater until the site construction has been completed and the site determined as stabilized by the City per City Ordinance 14-5-2-11 and CGP Part 4.2.2.  The silt fence and mulch socks were not installed according to the ESC Plan approved by the City in violation of CGP Part 2.1.3. Required mitigation: Complete installation of stormwater controls by the time each phase of construction activities has begun per CGP Part 2.1.3.  Discharge off site? (Y/N) no		Required mitigation: You must post a sign or other notice of your permit coverage at a safe, publicly					safe, publicly		
construction in violation of City Ordinance 14-5-2-11 and CGP Part 4.2. Required mitigation: At a minimum, a routine self-inspection is required to review the project for compliance with the Construction General Permit once every 14 days and after any precipitation event of 1/4 inch or greater until the site construction has been completed and the site determined as stabilized by the City per City Ordinance 14-5-2-11 and CGP Part 4.2.2.  The silt fence and mulch socks were not installed according to the ESC Plan approved by the City in violation of CGP Part 2.1.3. Required mitigation: Complete installation of stormwater controls by the time each phase of construction activities has begun per CGP Part 2.1.3.  Discharge off site? (Y/N) no		accessible loca							
minimum, a routine self-inspection is required to review the project for compliance with the Construction General Permit once every 14 days and after any precipitation event of 1/4 inch or greater until the site construction has been completed and the site determined as stabilized by the City per City Ordinance 14-5-2-11 and CGP Part 4.2.2.  The silt fence and mulch socks were not installed according to the ESC Plan approved by the City in violation of CGP Part 2.1.3. Required mitigation: Complete installation of stormwater controls by the time each phase of construction activities has begun per CGP Part 2.1.3.  Discharge off site? (Y/N) no	2	According to the superintendent of the site, there have been no self-inspections performed during							
Construction General Permit once every 14 days and after any precipitation event of 1/4 inch or greater until the site construction has been completed and the site determined as stabilized by the City per City Ordinance 14-5-2-11 and CGP Part 4.2.2.  The silt fence and mulch socks were not installed according to the ESC Plan approved by the City in violation of CGP Part 2.1.3. Required mitigation: Complete installation of stormwater controls by the time each phase of construction activities has begun per CGP Part 2.1.3.  Discharge off site? (Y/N) no		construction in violation of City Ordinance 14-5-2-11 and CGP Part 4.2. Required mitigation: At a					tion: At a		
Construction General Permit once every 14 days and after any precipitation event of 1/4 inch or greater until the site construction has been completed and the site determined as stabilized by the City per City Ordinance 14-5-2-11 and CGP Part 4.2.2.  The silt fence and mulch socks were not installed according to the ESC Plan approved by the City in violation of CGP Part 2.1.3. Required mitigation: Complete installation of stormwater controls by the time each phase of construction activities has begun per CGP Part 2.1.3.  Discharge off site? (Y/N) no		·							
greater until the site construction has been completed and the site determined as stabilized by the City per City Ordinance 14-5-2-11 and CGP Part 4.2.2.  The silt fence and mulch socks were not installed according to the ESC Plan approved by the City in violation of CGP Part 2.1.3. Required mitigation: Complete installation of stormwater controls by the time each phase of construction activities has begun per CGP Part 2.1.3.  Discharge off site? (Y/N) no									
City per City Ordinance 14-5-2-11 and CGP Part 4.2.2.  The silt fence and mulch socks were not installed according to the ESC Plan approved by the City in violation of CGP Part 2.1.3. Required mitigation: Complete installation of stormwater controls by the time each phase of construction activities has begun per CGP Part 2.1.3.  2.1 Discharge off site? (Y/N) no									
The silt fence and mulch socks were not installed according to the ESC Plan approved by the City in violation of CGP Part 2.1.3. Required mitigation: Complete installation of stormwater controls by the time each phase of construction activities has begun per CGP Part 2.1.3.  2.1 Discharge off site? (Y/N) no		<u> </u>					lized by the		
violation of CGP Part 2.1.3. Required mitigation: Complete installation of stormwater controls by the time each phase of construction activities has begun per CGP Part 2.1.3.  2.1 Discharge off site? (Y/N) no		City per City O	rdinance 14-5	2-11 and CGP Par	τ 4.2.2.				
time each phase of construction activities has begun per CGP Part 2.1.3.  2.1 Discharge off site? (Y/N) no	3	3 The silt fence and mulch socks were not installed according to the ESC Plan approved by					the City in		
time each phase of construction activities has begun per CGP Part 2.1.3.  2.1 Discharge off site? (Y/N) no						ontrols by the			
2.1 Discharge off site? (Y/N) no									
		'							
	2.1	Discharge off site?	(Y/N)	no					
		Self Inspect	tion Reports		Latest rei	oort Date:	N,	/A	

Notes:	
The ESC P	ermit approved by the City expired on April 1, 2025, although a search of the EPA database
	t the LEW was amended to extend the coverage through May. Performing land-disturbing without permit coverage can result in Formal Violations and financial penalties.

 ${\bf City\ of\ Albuquerque\ Stormwater\ Inspector\ Signature\ and\ date:}$ 

Contact information: Chancellor English (505) 924-3325

cenglish@cabq.gov