

Biazar, Shahab

From: Biazar, Shahab
Sent: Monday, October 21, 2013 4:56 PM
To: 'Thomas Johnston'
Cc: Sims, Timothy E.
Subject: RE: 330 Louisiana, CO request, (L18/D030)

Hi,

I have the following comments regarding your CO submittal for 330 Louisiana (L18/D030):

- 1) Change the certification language and include the changes on the drainage patterns from what was approved previously.
- 2) Add more spot elevations around the building.
- 3) How will the runoff drain to the street through the driveway?

Thanks and have a nice day.

I had the wrong drainage number on the email

Shahab Biazar, P.E.

Senior Engineer

Planning Department

Development & Building Services Division

600 2nd St. NW, Suite 201

Albuquerque, NM 87102

t 505-924-3695

f 505-924-3864