L18-D13

1 PLAN

City of Albuquerque
P.O. BOX 1293 ALBUQUERQUE, NEW MEXICO 87103

April 15, 1983

Mr. Chris Weiss, P.E.
CTS, Inc.
1100 B Alvarado N.E.
Albuquerque, New Mexico 87110

RE: 445 A & B GEORGIA ST. S.E.

Dear Chris:

The reference drainage plan is approved as designed. However, in an effort to curtail the volume of storm runoff to the rear of your client's property, I would recommend that you advise your client to route the roof runoff to Georgia St. via the drivepad.

Yours Truly,

Fred J. Aguirre
Civil Engineer/Hydrology

FJA/bes