HYDROLOGY L19/D11 ONE PLAN

L19/D11

1 PLAN

November 8, 1976

RECEIVED
NOV 0 9 1976
CITY ENGINEERS

Mr. Kleston Laws
Drainage Engineer
City of Albuquerque
P.O. Box 1293
Albuquerque, NM 87102

REFERENCE: Trumbull Community Center

Dear Mr. Laws:

Transmitted for your review is a drainage analysis for the Trumbull Community Center. After review, please advise this office if the submitted information is acceptable.

Very truly yours,

Thomas O. Isaacson

Thomas O. Isaacson
Senior Vice President

TOI:dd
Enclosure

cc: Mr. Ray Trujillo
File #1176-1

Chambers, Campbell, Isaacson, Chaplin, Inc.
architects engineers planners 3500 indian school road ne albuquerque new mexico 87106 505/266-5521

November 15, 1976

L17-D11

Mr. Thomas O. Isaacson
C.C.I.C.
3500 Indian School Rd. N.E.
Albuquerque, New Mexico 87106

RE: TRUMBULL COMMUNITY CENTER

Dear Mr. Isaacson:

The drainage report is acceptable. The offsite flow to be deflected should probably be on the subject property. It does not seem proper to cause the deflection on another's land.

The building plans should include the finish floor elevation and details on the parking lot grading.

Very truly yours,

Kleston H. Laws
Assistant City Engineer-Hydrology

KHL/fs

Nov 15 1976

Thomas O. Isaacson
Chambers, Campbell, Isaacson, Chaplin Inc
3500 Indian School Rd NE
Albuquerque NM 87106

Re: Trumbull Community Center.

Dear Mr. Isaacson:

The drainage report is acceptable. The offsite flow to be deflected should probably be on the subject property. It does not seem proper to cause the deflection on another's land.

The building plans should include the finish floor elevation and details on the parking lot grading.

Very truly yours,

Kleton H Lewis

letter of transmittal

Chambers, Campbell, Isaacson, Chaplin, Inc.
architects, engineers, planners 3500 indian school road ne albuquerque new mexico 87106 505-266-5521

DATE: 3-28-77

JOB NO:

TRANSMITTAL NO:

PROJECT: Trumbull Community Center

TO: City Hydrology Engineer L19-D11
City of Albuquerque
New Mexico

ATTENTION:

RECEIVED
MAR 31 1977
CITY ENGINEERS

Gentlemen:

We are sending you ☒ attached ☐ under separate cover via

1 copies/sets of the following:

- ☐ Shop Drawings
- ☐ Descriptive Literature
- ☐ Copy of Letter
- ☐ Certifications
- ☐ Samples
- ☒ Reduced drawing of Site Plan w/ add. topo.

PREPARED BY:

COVERING:

SPEC. SEC.

These are transmitted as checked below:

- ☐ Approved as Submitted
- ☐ Approved as Noted
- ☐ Disapproved as Noted
- ☐ Returned for Corrections
- ☐ Resubmit _____ Copies for Approval
- ☐ Resubmit _____ Corrected Copies for Record
- ☐ For Approval
- ☒ For Information and File
- ☐ For Review and Comment
- ☐ For Your Use
- ☐
- ☐

REMARKS: We are forwarding information requested - Additional topo of lot to north of site, and area, rate of flow flowing toward site, and pond volume available as per site plan.

COPY TO: Ray Trujillo, Architect

BY: Chas Chaplin
CHAMBERS, CAMPBELL, ISAACSON & CHAPLIN, INC.


LOVELACE
FOUNDATION
TRACT
U S GOV'T LAND
FEDERAL AID LOOP
LANDS OF BOARD OF EDUCATION
SOUTHERN
ADD.

L-19-Z