



TREASURY DIVISION DAILY DEPOSIT

Transmittals for:  
PROJECTS Only

Payment-in-Lieu for Storm Water Quality  
Volume Requirement

| CASH COUNT   | AMOUNT     | ACCOUNT<br>NUMBER | FUND<br>NUMBER | BUSINESS<br>UNIT | PROJECT ID | ACTIVITY<br>ID | AMOUNT         |
|--------------|------------|-------------------|----------------|------------------|------------|----------------|----------------|
| TOTAL CHECKS | \$ 1408.00 | 461615            | 305            | PCDMD            | 24_MS4     | 7547210        | 1408.00        |
|              |            |                   |                |                  |            |                |                |
| TOTAL AMOUNT |            |                   |                |                  |            | TOTAL DEPOSIT  | <b>1408.00</b> |
|              |            |                   |                |                  |            |                |                |

Hydrology#: L20D079 Name: Nationwide Building Enterprises LLC  
Payment In-Lieu for Storm Water Quality  
Volume Requirement


Address/Legal Description: 9324 Susan Avenue SE

DEPARTMENT NAME: Planning Department/Development Review Services, Hydrology

PREPARED BY Yolanda J Montoya PHONE 505-924-3861

BUSINESS DATE December 20, 2024

DUAL VERIFICATION OF DEPOSIT   
EMPLOYEE SIGNATURE

AND BY   
EMPLOYEE SIGNATURE

REMITTER: \_\_\_\_\_

AMOUNT: \_\_\_\_\_

BANK: \_\_\_\_\_

CHECK #: \_\_\_\_\_ DATE ON CHECK: \_\_\_\_\_

The Payment-in-Lieu can be paid at the Plaza del Sol Treasury, 600 2<sup>nd</sup> St. NW. **Bring three copies of this invoice to the Treasury** and provide a copy of the receipt to Hydrology, Suite 201, 600 2<sup>nd</sup> St. NW, or e-mail with the Hydrology submittal to [PLNDRS@cabq.gov](mailto:PLNDRS@cabq.gov).

City of Albuquerque


Reference Number: 2024355003-12  
Date/Time: 12/20/2024 3:57:11 PM

Departmental Deposit  
2024355003-12-1  
Departmental Deposit 1@ \$1,408.00  
GL #: 130514616151PCDMD124MS4175472101  
Total: \$1,408.00

1 ITEM TOTAL: \$1,408.00  
TOTAL: \$1,408.00

\*DUPLICATE RECEIPT 12/20/2024 3:58:08 PM\*

Check \$1,408.00  
Bank Account #: \*\*\*\*\*0024  
Check Number: 01134  
Bank Routing #: \*\*\*\*\*4211  
Address:  
Total Received: \$1,408.00



Thank you for your payment.

**CITY OF ALBUQUERQUE  
PLANNING DEPARTMENT  
HYDROLOGY DEVELOPMENT SECTION**

**WAIVER APPLICATION FROM STORMWATER  
QUALITY VOLUME MANAGEMENT ON-SITE**

---

**GENERAL INFORMATION**

---

APPLICANT: ~~ANNETTE VIGH~~ NATIONWIDE DATE: 12-19-24  
BUILDING ENTERPRISES LLC  
DEVELOPMENT: \_\_\_\_\_  
LOCATION: 9324 SUSAN AVENUE SE

---

---

**STORMWATER QUALITY POND VOLUME**

---

Per the DPM Article 6-12 - Stormwater Quality and Low-Impact Development, the calculated sizing for required Stormwater Quality Pond volume is equal to the impervious area draining to the BMP multiplied by 0.42 inches for new development sites and by 0.26 inches for redevelopment sites.

The required volume is 176 cubic feet

The provided volume is 0 cubic feet

The deficient volume is 176 cubic feet

---

**WAIVER JUSTIFICATION**

---

Per the DPM Article 6-12(C), private off-site mitigation and payment-in-lieu may only be considered if management on-site is waived in accordance with the following criteria and procedures.

1. Management on-site shall be waived by the City Engineer if the following conditions are met:

- a. Stormwater quality can be effectively controlled through private off-site mitigation or through an arrangement (approved by the City) to use a cooperator's existing regional stormwater management infrastructure or facilities that are available to control stormwater quality.
- b. Any of the following conditions apply:
  - i. The lot is too small to accommodate management on site while also accommodating the full plan of development.
  - ii. The soil is not stable as demonstrated by a geotechnical report certified by a professional engineer licensed in the State of New Mexico.
  - iii. The site use is inconsistent with the capture and reuse of stormwater.
  - iv. Other physical conditions exist where compliance with on-site stormwater quality control leaves insufficient area.
  - v. Public or private off-site facilities provide an opportunity to effectively accomplish the mitigation requirements of the Drainage Ordinance (Part 14-5-2 ROA 1994) as demonstrated on as-built construction drawings and an approved drainage report.
  - vi. The developer constructs a project to replenish regional groundwater supplies at an off-site location.
  - vii. A waiver to State water law or acquisition of water rights would be required in order to implement management on site.
2. The basis for requesting payment-in-lieu or private off-site mitigation is to be clearly demonstrated on the drainage plan.

This project's justification:

The lot is too small to accommodate on site management after development is complete.

Stephen M. Rodriguez  
\_\_\_\_\_  
Professional Engineer or Architect

---

## PAYMENT-IN-LIEU

---

Per the DPM Article 6-12(C)(1), the amount of payment-in-lieu is deficient volume (cubic feet) times \$6 per cubic feet for detached single-family residential projects or \$8 per cubic feet for all other projects.

AMOUNT OF PAYMENT-IN-LIEU = \$ 1408.00 (176 x 8)

---

**THIS SECTION IS FOR CITY USE ONLY**

---

☒

Waiver is approved. The amount of payment-in-lieu from above must be paid prior to Certificate of Occupancy.

☐

Waiver is DENIED.



---

City of Albuquerque  
Hydrology Section