

# CITY OF ALBUQUERQUE



March 3, 2015

Troy Kelts, P.E.  
Merrick & Company  
5970 Greenwood Plaza Blvd  
Greenwood Village, CO 80015

RE: **Chick-fil-A**  
**210 Eubank Blvd SE**  
**Grading and Drainage Plan**  
**Engineers Stamp Date None (L21D045B)**

Dear Mr. Kelts,

Based upon the information provided in your submittal received 2/2/2015, the above referenced Grading and Drainage Plan cannot be approved for Grading Permit or Building Permit until the following comments are addressed.

- Mention of the first flush per EPA standards is required and placed on the plans. The amount required is .34" times the impervious area. Place the inlets in the landscape islands/areas for first flush requirements.
- The dumpster area must contain a drain connected to the SAS, with a grease trap.
- Provide Engineer stamp, date and signature.

PO Box 1293

Albuquerque

New Mexico 87103

[www.cabq.gov](http://www.cabq.gov)

If you have any questions please contact me at 924-3986 or Rudy Rael at 924-3977.

Sincerely,

Curtis Cherne, P.E.  
Principal Engineer, Hydrology  
Planning Department

RR/CC  
C: File