HYDROLOGY L22/D27 ONE PLAN

L 22/D 27

1 PLAN

12701 Central NW. 9-6-80

disapproved

① show existing & proposed contours, 1 ft. intervals

② show direction of roof drainage & means of conveyance

③ need more spot elevations.

④ describe offsite flows

⑤ at new curbcut, the elev. at the property line must be .33' above top of curve.

⑥ DEFICIENT IN GRADES.