

CITY OF ALBUQUERQUE

Hydrology Section Planning Department
Brennon Williams, Director



Timothy M. Keller, Mayor

March 3, 2020

Mike Keenan – Keenan820@yahoo.com
Dalton@morebrothers.com

Site: Keenan Properties - 12900 Central SE - L22E061

Re: Drainage Ordinance (14-5-2-1) Violations for Erosion and Sediment Control

The following violations were observed at today's inspection.

1. BMPs were not installed in accordance with the approved ESC Plan.
2. NPDES ID was not posted at a publicly accessible location.

Photos are shown below.



PO Box 1293

Albuquerque

NM 87103

www.cabq.gov


Required Mitigation:

1. Install and maintain BMPs
2. Post NPDES ID and contact information.

If the violations are not mitigated within 7 days, the property owner is subject to a fine of \$500/day per the City's Drainage Control Ordinance.

If you have any questions, you can contact me at 924-3420 or jhughes@cabq.gov

Sincerely,

A handwritten signature in blue ink, appearing to read "James D. Hughes".

James D. Hughes, P.E.

Principal Engineer, Hydrology/Stormwater Quality
Planning Dept.