From: Patz, Logan W.
To: "Martin J. Garcia"
Cc: "kennan820@yahoo.com"; Maadandar, Mojgan
Subject: Kennan Properties, 12900 Central Ave SE, TCL L22D061
Date: Wednesday, June 27, 2018 12:36:00 PM
Importance: High

Hello,

There are a few comments that need to be address before I can approve the TCL.

- The parking spaces at the north end (front) of the site are missing a length dimension.
- The employee parking needs to be dimensioned and show the outlines of the spaces on the plan.
- List the type of material the surface is made of in the employee parking on the plan.
- Label the canopy as a canopy on the plans, it is listed as a building.

I will be able to approve the TCL after the remaining comments are addressed. Let me know if you have any questions.

Thank you.

Logan Patz
Planning Department
Transportation Development
600 2nd St. NW, Suite 201
Albuquerque, NM 87102
505-924-3630